

AERCO INTERNATIONAL, INC.

SCAQMD RULE 1146.2 CERTIFICATION LIST

(Type 2 Units Certified @ 14 ng/J NOx or 20 ppm @ 3% O2)

All modulating/condensing type

INNOVATION	Heat Input, Max/Min (Btu/Hr)
INN 600	600,000/45,000
INN 650	650,000/45,000
INN 750	750,000/45,000
INN 800	800,000/45,000
INN 850	850,000/45,000
INN 975	975,000/45,000
INN 1060	1,060,000/45,000

May 5, 2011

Mr. Earl J. Rightmier Aerco International, Inc. 159 Paris Avenue Northvale, NJ 07647

Thank you for your participation in the Rule 1146.2 Administrative Certification Program. As requested in your letter dated March 24, 2011, the certified models and other particulars are as follows:

Models	See attached table	
Boiler Type per	2	
Rule 1146.2		
Source Test (S/T)	Gas Consultants, Inc.	
conducted by	Gas Consultants, Inc.	
S/T Report date	November 24, 2010	
AQMD S/T Nos.	R11193	
NOx Compliance	14 ng/J or 20 ppm @ 3% O2	
R1146.2(c)(7)		
Rule 1146.2	Meets 14 ng/J or 20 ppm NOx @ 3% O ₂	
Certification	Weets 14 lig/J of 20 ppin NOX (2) 3/8 O2	

Please note that the District does not endorse or warrant any specific product or manufacturer. Modification of the products listed above will void this certification. If you have any questions or require further assistance, please contact Raman Patel at (909) 396-2466 or by e-mail at rpatel@aqmd.gov.

Sincerely,

Raman C. Patel, P.E.

Senior Air Quality Engineer Area Sources (PRDAS)

cc: File: Aerco