

PLUMBING FIXTURE UNIT TABLES

HOTELS/MOTELS

| 110 1223/1110 1223 | |
|-------------------------|---------------|
| Type of Fixture | Fixture Units |
| Barber Basin | 2.0 |
| Beauty Parlor Basin | 2.5 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.5 |
| Private Shower | 1.5 |
| Domestic Kitchen Sink | 1.5 |
| Slop Sink | 2.5 |
| Domestic Clothes Washer | 1.2 |

APARTMENT COMPLEXES/CONDOMINIUMS

| Fixture Units |
|---------------|
| 1.5 |
| 0.75 |
| 1.0 |
| 1.5 |
| 1.5 |
| 1.5 |
| 0.75 |
| 1.5 |
| 1.5 |
| 1.2 |
| 1.5 |
| |

NURSING HOMES, ASSISTED LIVING

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| Janitor Drop | 2.0 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.5 |
| Private Shower | 1.5 |
| Domestic Kitchen Sink | 1.5 |
| Slop Sink | 2.0 |
| Domestic Clothes Washer | 2.0 |
| Domestic Dish Washer | 1.5 |

SCHOOLS - ELEMENTARY, MIDDLE , HIGH SCHOOLS, &

| IVIID DEL , I II GIT SCITO | MIDDEE , MICH SCHOOLS, G | |
|----------------------------|--------------------------|--|
| Type of Fixture | Fixture Units | |
| Janitor Drop | 1.5 | |
| Laundry Tray | 2.0 | |
| Private Lavatory | 0.75 | |
| Public Lavatory | 1.0 | |
| Shower and Tub | 1.7 | |
| Private Shower | 1.5 | |
| Public Shower | 3.0 | |
| Domestic Kitchen Sink | 0.75 | |
| Laboratory Sink | 1.5 | |
| Pantry Sink | 2.5 | |
| Slop Sink | 1.5 | |
| Domestic Clothes Washer | 2.0 | |
| Domestic Dish Washer | 2.0 | |

UNIVERSITY/COLLEGE DORMITORIES

| Type of Fixture | Fixture Units |
|---|---------------|
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.5 |
| Private Shower | 1.5 |
| Public Shower | 1.5 |
| Domestic Kitchen Sink | 1.5 |
| Slop Sink | 2.5 |
| Domestic Clothes Washer | 2.0 |
| Domestic Dish Washer | 2.0 |
| Domestic Kitchen Sink Slop Sink Domestic Clothes Washer | 2 2 |

HEALTH CLUBS, SPAS, AND COUNTRY CLUBS

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| Foot Basin | 1.2 |
| Laundry Tray | 2.5 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.5 |
| Private Shower | 1.5 |
| Public Shower | 1.7 |
| Domestic Kitchen Sink | 1.5 |
| Pantry Sink | 1.5 |
| Slop Sink | 2.5 |
| Wash Fountain, 36" Half | 1.0 |
| Wash Fountain, 36" Full | 2.0 |
| Wash Fountain, 54" Half | 1.5 |
| Wash Fountain, 54" Full | 2.5 |
| Domestic Clothes Washer | 2.0 |

OFFICE, COMMERCIAL, RETAIL

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| Janitor Drop | 2.5 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Private Shower | 1.5 |
| Slop Sink | 2.5 |
| Wash Fountain, 36" Half | 1.0 |
| Wash Fountain, 36" Full | 1.5 |



PLUMBING FIXTURE UNIT TABLES

HOSPITALS, MEDICAL FACILITIES, PSYCHIATRIC CENTERS

| Type of Fixture | Fixture Units |
|----------------------------------|---------------|
| Therapeutic Bath | 5.0 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Private Shower | 1.5 |
| Semi Private Shower | 1.5 |
| General Purpose Sink | 1.0 |
| Domestic Kitchen Sink | 3.0 |
| Laboratory Sink | 1.5 |
| Pantry Sink | 2.5 |
| Slop Sink | 2.5 |
| Autopsy, Sink & Table | 2.5 |
| Autopsy Table | 2.0 |
| Bath, Arm | 4.0 |
| Continuous Flow Fill Bath | 2.0 |
| Continuous Flow Operate Bath | 1.5 |
| Emergency Bath | 2.0 |
| Bath, Foot | 3.0 |
| Bath, Leg | 6.0 |
| Private Bath | 1.5 |
| Sitz Bath | 3.0 |
| Ward Bath | 2.0 |
| Hubbard Tank | 4.0 |
| Hydrotheraputic Shower, #1 Head | 8.0 |
| Hydrotheraputic Shower, #2 Spray | 12 |
| Ward Shower | 2.5 |
| Flushing Rim Sink | 2.0 |
| Scrub-Up Sink | 1.5 |

PRISONS AND CORRECTIONAL FACILITIES

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| Janitor Drop | 2.0 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.5 |
| Private Shower | 1.5 |
| Public Shower | 3.0 |
| Slop Sink | 2.0 |
| Wash Fountain, 36" Half | 1.0 |
| Wash Fountain, 36" Full | 2.0 |
| Wash Fountain, 54" Half | 1.5 |
| Wash Fountain, 54" Full | 2.5 |

YMCA/YWCA

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| | |
| Therapeutic Bath | 6.0 |
| Janitor Drop | 2.0 |
| Laundry Tray | 2.0 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.7 |
| Private Shower | 1.5 |
| Public Shower | 3.0 |
| Domestic Kitchen Sink | 3.0 |
| Pantry Sink | 2.5 |
| Slop Sink | 2.5 |
| Wash Fountain, 36" Half | 1.0 |
| Wash Fountain, 36" Full | 1.5 |
| Domestic Clothes Washer | 2.0 |

GYMNASIUMS , FIELD HOUSE, STADIUM, ARENA, MILITARY

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| Foot Basin | 1.2 |
| Therapeutic Bath | 6.0 |
| Private Lavatory | 0.75 |
| Public Lavatory | 1.0 |
| Shower and Tub | 1.5 |
| Private Shower | 1.5 |
| Public Shower | 3.0 |
| Wash Fountain, 36" Half | 1.0 |
| Wash Fountain, 36" Full | 2.0 |
| Wash Fountain, 54" Half | 1.5 |
| Wash Fountain, 54" Full | 2.5 |
| Domestic Clothes Washer | 1.2 |

INDUSTRIAL PLANT

| Type of Fixture | Fixture Units |
|-------------------------|---------------|
| Private Lavatory | 0.75 |
| Public Lavatory | 2.0 |
| Private Shower | 1.5 |
| Public Shower | 3.0 |
| General Purpose Sink | 2.5 |
| Domestic Kitchen Sink | 3.0 |
| Slop Sink | 2.5 |
| Wash Fountain, 36" Half | 1.5 |
| Wash Fountain, 36" Full | 3.0 |
| Wash Fountain, 54" Half | 2.0 |
| Wash Fountain, 54" Full | 4.0 |

RESTAURANT

| RESTAURANT | |
|-------------------------|---------------|
| Type of Fixture | Fixture Units |
| Private Lavatory | 0.75 |
| Public Lavatory | 2.0 |
| Private Shower | 1.5 |
| Public Shower | 1.7 |
| Pantry Sink | 2.5 |
| Slop Sink | 2.0 |
| Wash Fountain, 36" Half | 1.0 |
| Wash Fountain, 36" Full | 1.5 |
| Baine Marie | 1.0 |
| Coffee Urn | 1.2 |
| Bar Sink | 2.5 |
| Kitchen Sink | 3.0 |
| Single Pot Sink | 2.5 |
| Double Pot Sink | 3.5 |
| Triple Pot Sink | 5.5 |
| Vegetable Sink | 2.0 |
| Can Washer | 3.0 |
| Pre-Rinse Dish Washer | 2.5 |
| Glass Washer | 2.0 |
| Pot & Pan Washer | 2.0 |
| Pre-Scaper Washer | 2.0 |
| Pre-Scraper Conveyor | 2.5 |
| Silver Washer | 2.0 |
| | |



TEMPERATURE CORRECTION FACTOR

AERCO sizing guidelines for selecting the number of gas fired units are based on 40°F entering cold water, 110°F mixed temperature at the fixtures, and no greater than 140°F heater set point. To select properly for alternate cold water inlet temperatures, a temperature correction factor may be applied:

| Тс | 40°F | 45°F | 50°F | 55°F | 60°F | 65°F | 70°F | 75°F | 80°F |
|-----|------|------|------|------|------|------|------|------|------|
| TCF | 1 | 0.98 | 0.95 | 0.92 | 0.89 | 0.86 | 0.82 | 0.77 | 0.71 |

Example: An apartment building has a total calculated fixture unit count of 400. The operating conditions will be 50 to 130°F and the system design should incorporate 100% redundant capacity.

Step 1: Go to the table on Page D300.17 "APARTMENT COMPLEXES/CONDOMINIUMS, Domestic Water Inlet - Outlet Conditions: 40-130 °F" and determine the total heater capacity required for 400 fixture units @ "200% Design Load" (100% redundant capacity). The required system flow is **59.7** GPM @ 40 -130 °F.

Step 2: From the chart above multiply the temperature correction factor (TCF) for 50° F by 59.7 GPM to determine the corrected required system flow at the higher inlet water temperature; .95 X 59.7 = **56.7** GPM

Step 3: Determine the number of INNOVATION heaters required to meet this demand - 56.7 GPM @ 50 to 130°F. Since this is an 80°F temperature rise, go to the lower table on Page D300.30 labeled "Maximum Unit Capacity (GPM), 40-120 °F" to find the lowest quantity of multple units required to meet this load. The table shows that 3 - **INN800's** meet the requirement of this application.



HOTELS/MOTELS - MIXED OCCUPANCY

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 10.1 | 1 | | | | 15.2 | 2 | | | | 20.3 | 2 | | | |
| 50 | 13.2 | | 1 | | | 19.8 | 2 | | | | 26.4 | | 2 | | |
| 100 | 18.2 | | | 1 | | 27.4 | | 2 | | | 36.5 | | | 2 | |
| 150 | 20.3 | | | 1 | | 30.4 | | 2 | | | 40.6 | | | 2 | |
| 200 | 23.1 | | | | 1 | 34.6 | | | 2 | | 46.1 | | | | 2 |
| 250 | 25.3 | | | | 1 | 38.0 | | | 2 | | 50.6 | | | | 2 |
| 300 | 27.2 | | 2 | | | 40.8 | | | 2 | | 54.5 | | | 3 | |
| 350 | 29.3 | | 2 | | | 44.0 | | | | 2 | 58.7 | | | 3 | |
| 400 | 30.8 | | 2 | | | 46.2 | | | | 2 | 61.2 | | | 3 | |
| 550 | 36.1 | | | 2 | | 54.1 | | | 3 | | 72.1 | | | | 3 |
| 700 | 40.6 | | | 2 | | 60.9 | | | 3 | | 81.2 | | | 4 | |
| 1000 | 50.6 | | | | 2 | 75.8 | | | | 3 | 101.1 | | | | 4 |
| 1200 | 52.4 | | | | 2 | 78.6 | | | | 3 | 104.8 | | | | 4 |
| 1500 | 63.8 | | | | 3 | 95.8 | | | | 4 | 131.0 | | | | 5* |
| 1800 | 74.4 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 2200 | 78.6 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 3000 | 102.0 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



HOTELS/MOTELS - CONVENTION CENTER/BUSINESS MEETING

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 14.4 | | 1 | | | 21.5 | 2 | | | | 28.7 | | 2 | | |
| 50 | 18.7 | | | 1 | | 28.1 | | 2 | | | 37.4 | | | 2 | |
| 100 | 25.8 | | 2 | | | 38.8 | | | 2 | | 51.7 | | | | 2 |
| 150 | 30.3 | | 2 | | | 45.4 | | | | 2 | 60.5 | | | 3 | |
| 200 | 33.2 | | | 2 | | 49.9 | | | | 2 | 66.5 | | | | 3 |
| 250 | 35.9 | | | 2 | | 53.8 | | | 3 | | 71.7 | | | | 3 |
| 300 | 38.6 | | | 2 | | 57.9 | | | 3 | | 77.2 | | | | 3 |
| 350 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 4 | |
| 400 | 44.7 | | | | 2 | 67.1 | | | | 3 | 89.4 | | | | 4 |
| 550 | 51.1 | | | | 2 | 76.6 | | | | 3 | 102.2 | | | | 4 |
| 700 | 59.5 | | | 3 | | 89.3 | | | | 4 | 119.0 | | | | 5 |
| 1000 | 72.8 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1200 | 78.6 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1500 | 90.4 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |
| 1800 | 104.8 | | | | 4 | 131.0 | · | | | 5* | 157.2 | | · | | 6* |
| 2200 | 119.0 | | | | 5 | 157.2 | | | | 6* | 183.4 | | | | 7* |
| 3000 | 149.8 | | | | 6 | 183.4 | | | | 7* | 209.6 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



APARTMENT COMPLEXES/CONDOMINIUMS

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlin | oles @ 15 | 0% Design | n Load | 200% Design | Multir | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|---|---------|---|-------------|--------|-----------|-----------|--------|-------------|--------|-----------|-----------|--------|
| Unit Count | _ | INN600 | | INN1060 | | _ | INN600 | | INN1060 | | Load (GPM) | INN600 | | INN1060 | |
| 25 | 8.6 | 1 | | | | 12.9 | 2 | | | | 17.2 | 2 | | | |
| 50 | 11.4 | 1 | | | | 17.1 | 2 | | | | 22.8 | 2 | | | |
| 100 | 15.1 | | 1 | | | 22.6 | 2 | | | | 30.2 | | 2 | | |
| 150 | 18.0 | | | 1 | | 27.0 | | 2 | | | 36.0 | | | 2 | 2 |
| 200 | 20.1 | | | 1 | | 30.1 | | 2 | | | 40.2 | | | 2 | 2 |
| 250 | 21.8 | | | | 1 | 32.8 | | | 2 | | 43.7 | | | | 2 |
| 300 | 23.0 | | | | 1 | 34.5 | | | 2 | | 46.0 | | | | 2 |
| 350 | 25.0 | | | | 1 | 37.4 | | | 2 | | 49.9 | | | | 2 |
| 400 | 26.9 | | 2 | | | 40.4 | | | 2 | | 53.8 | | | 3 | |
| 550 | 32.2 | | | 2 | | 48.3 | | | | 2 | 64.4 | | | | 3 |
| 700 | 36.8 | | | 2 | | 55.2 | | | 3 | | 73.6 | | | | 3 |
| 1000 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 4 | |
| 1200 | 47.8 | | | | 2 | 71.8 | | | | 3 | 95.7 | | | | 4 |
| 1500 | 52.4 | | | | 2 | 78.6 | | | | 3 | 104.8 | | | | 4 |
| 1800 | 58.5 | | | 3 | | 87.8 | | | | 4 | 117.0 | | | | 5 |
| 2200 | 64.9 | | | | 3 | 97.3 | | | | 4 | 129.7 | | | | 5 |
| 3000 | 84.4 | | | | 4 | 126.6 | | | | 5 | 157.2 | | | | 6* |

| Maxim | Maximum Unit Capacity (GPM), 40-140 °F | | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | | |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 | | | | | | | | | |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 | | | | | | | | | |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 | | | | | | | | | |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 | | | | | | | | | |
| 5 | 58 | 77 | 102 | 131 | | | | | | | | | |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 | | | | | | | | | |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 | | | | | | | | | |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 | | | | | | | | | |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 | | | | | | | | | |
| 10 | 116 | 154 | 204 | 262 | | | | | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



NURSING HOMES, ASSISTED LIVING

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlir | nles @ 15 | 0% Design | n Load | 200% Design | 200% Design Multiples @ 200% Design Lo | | | n Load |
|------------|-------------|--------|---|---------|-----------|-------------|--------|-----------|-----------|---------|-------------|--|---|---------|---------|
| Unit Count | _ | | | | ININI1250 | _ | | | | | _ | | | | |
| | (- , | INN600 | | INN1060 | INN1350 | ` , | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | | INN1060 | INN1350 |
| 25 | 14.4 | | 1 | | | 21.5 | 2 | | | | 28.7 | | 2 | | |
| 50 | 18.7 | | | 1 | | 28.1 | | 2 | | | 37.4 | | | 2 | |
| 100 | 25.8 | | 2 | | | 38.8 | | | 2 | | 51.7 | | | | 2 |
| 150 | 30.3 | | 2 | | | 45.4 | | | | 2 | 60.5 | | | 3 | |
| 200 | 33.2 | | | 2 | | 49.9 | | | | 2 | 66.5 | | | | 3 |
| 250 | 35.9 | | | 2 | | 53.8 | | | 3 | | 71.7 | | | | 3 |
| 300 | 38.6 | | | 2 | | 57.9 | | | 3 | | 77.2 | | | | 3 |
| 350 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 4 | |
| 400 | 44.7 | | | | 2 | 67.1 | | | | 3 | 89.4 | | | | 4 |
| 550 | 51.1 | | | | 2 | 76.6 | | | | 3 | 102.2 | | | | 4 |
| 700 | 59.5 | | | 3 | | 89.3 | | | | 4 | 119.0 | | | | 5 |
| 1000 | 72.8 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1200 | 78.6 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1500 | 90.4 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |
| 1800 | 104.8 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |
| 2200 | 119.0 | _ | | | 5 | 157.2 | | _ | | 6* | 183.4 | | | | 7* |
| 3000 | 149.8 | | | | 6 | 183.4 | | | | 7* | 209.6 | | | | 8* |

| Maxim | Maximum Unit Capacity (GPM), 40-140 °F | | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | | |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 | | | | | | | | | |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 | | | | | | | | | |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 | | | | | | | | | |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 | | | | | | | | | |
| 5 | 58 | 77 | 102 | 131 | | | | | | | | | |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 | | | | | | | | | |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 | | | | | | | | | |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 | | | | | | | | | |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 | | | | | | | | | |
| 10 | 116 | 154 | 204 | 262 | | | | | | | | | |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



HOSPITALS, MEDICAL FACILITIES, PSYCHIATRIC CENTERS

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture Design Load Design Load 150% Design | | | | | | N 4±1: | -l @ 4F | 00/ D! | | | N 4 lat. | -1 @ 20 | 00/ Dasies | - 1 1 | |
|---|-------|--------|--------|---------|---------|-------------|---------|-----------|---------|---------|-------------|---------|------------|-----------|---------|
| | _ | | | | | 150% Design | • | oles @ 15 | | | 200% Design | | | 0% Desigr | |
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 14.4 | | 1 | | | 21.5 | 2 | | | | 28.7 | | 2 | | |
| 50 | 18.7 | | | 1 | | 28.1 | | 2 | | | 37.4 | | | 2 | |
| 100 | 25.8 | | 2 | | | 38.8 | | | 2 | | 51.7 | | | | 2 |
| 150 | 30.3 | | 2 | | | 45.4 | | | | 2 | 60.5 | | | 3 | |
| 200 | 33.2 | | | 2 | | 49.9 | | | | 2 | 66.5 | | | | 3 |
| 250 | 35.9 | | | 2 | | 53.8 | | | 3 | | 71.7 | | | | 3 |
| 300 | 38.6 | | | 2 | | 57.9 | | | 3 | | 77.2 | | | | 3 |
| 350 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 4 | |
| 400 | 44.7 | | | | 2 | 67.1 | | | | 3 | 89.4 | | | | 4 |
| 550 | 51.1 | | | | 2 | 76.6 | | | | 3 | 102.2 | | | | 4 |
| 700 | 59.5 | | | 3 | | 89.3 | | | | 4 | 119.0 | | | | 5 |
| 1000 | 72.8 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1200 | 78.6 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1500 | 90.4 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |
| 1800 | 104.8 | | | | 4 | 131.0 | · | | | 5* | 157.2 | | | | 6* |
| 2200 | 119.0 | | | | 5 | 157.2 | | | | 6* | 183.4 | | | | 7* |
| 3000 | 149.8 | | | · | 6 | 183.4 | · | | | 7* | 209.6 | · | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



SCHOOLS - ELEMENTARY, MIDDLE, HIGH SCHOOLS, AND COLLEGES

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | Desigi | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 7.4 | 1 | | | | 11.1 | 2 | | | | 14.8 | 2 | | | |
| 50 | 10.0 | 1 | | | | 15.0 | 2 | | | | 20.0 | 2 | | | |
| 100 | 14.3 | | 1 | | | 21.5 | 2 | | | | 28.6 | | 2 | | |
| 150 | 17.6 | | | 1 | | 26.3 | | 2 | | | 35.1 | | | 2 | |
| 200 | 19.9 | | | 1 | | 29.8 | | 2 | | | 39.8 | | | 2 | |
| 250 | 21.2 | | | | 1 | 31.9 | | | 2 | | 42.5 | | | | 2 |
| 300 | 22.1 | | | | 1 | 33.2 | | | 2 | | 44.3 | | | | 2 |
| 350 | 23.0 | | | | 1 | 34.6 | | | 2 | | 46.1 | | | | 2 |
| 400 | 24.8 | | | | 1 | 37.1 | | | 2 | | 49.5 | | | | 2 |
| 550 | 29.6 | | 2 | | | 44.4 | | | | 2 | 59.2 | | | 3 | |
| 700 | 33.9 | | | 2 | | 50.9 | | | | 2 | 67.9 | | | | 3 |
| 1000 | 40.6 | | | 2 | | 60.9 | | | 3 | | 81.2 | | | | 4 |
| 1200 | 45.5 | | | | 2 | 68.3 | | | | 3 | 91.1 | | | | 4 |
| 1500 | 51.0 | | | | 2 | 76.5 | | | | 3 | 102.1 | | | | 4 |
| 1800 | 54.3 | | | 3 | | 81.4 | | | 4 | | 108.5 | | | | 5 |
| 2200 | 60.8 | - | - | 3 | | 91.1 | | - | | 4 | 121.5 | | | | 5 |
| 3000 | 76.6 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.



UNIVERSITY/COLLEGE DORMITORIES

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | Desigi | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 15.2 | | 1 | | | 22.8 | 2 | | | | 30.4 | | 2 | | |
| 50 | 19.8 | | | 1 | | 29.7 | | 2 | | | 39.6 | | | 2 | |
| 100 | 27.2 | | 2 | | | 40.8 | | | 2 | | 54.4 | | | 3 | |
| 150 | 30.6 | | 2 | | | 45.9 | | | | 2 | 61.2 | | | 3 | |
| 200 | 35.0 | | | 2 | | 52.4 | | | | 2 | 69.9 | | | | 3 |
| 250 | 38.0 | | | 2 | | 57.0 | | | 3 | | 76.0 | | | | 3 |
| 300 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 4 | |
| 350 | 44.0 | | | | 2 | 66.0 | | | | 3 | 88.0 | | | | 4 |
| 400 | 47.3 | | | | 2 | 71.0 | | | | 3 | 94.7 | | | | 4 |
| 550 | 54.1 | | | 3 | | 81.1 | | | 4 | | 108.2 | | | | 5 |
| 700 | 61.2 | | | 3 | | 91.8 | | | | 4 | 122.4 | | | | 5 |
| 1000 | 77.1 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1200 | 85.1 | | | | 4 | 127.7 | | | | 5 | 157.2 | | | | 6* |
| 1500 | 95.8 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |
| 1800 | 111.6 | | | | 5 | 157.2 | | | | 6* | 183.4 | | | | 7* |
| 2200 | 122.4 | | | · | 5 | 157.2 | | · | | 6* | 183.4 | | | | 7* |
| 3000 | 157.2 | | | | 6 | 183.4 | | | | 7* | 209.6 | | | | 8* |

| Maxim | num Unit Capacity (GPM), 40-140 °F INN600 INN800 INN1060 INN1350 11.6 15.4 20.4 26.2 23.2 30.8 40.8 52.4 34.8 46.2 61.2 78.6 46.4 61.6 81.6 104.8 58 77 102 131 69.6 92.4 122.4 157.2 81.2 107.8 142.8 183.4 | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 | | | | | |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 | | | | | |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 | | | | | |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 | | | | | |
| 5 | 58 | 77 | 102 | 131 | | | | | |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 | | | | | |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 | | | | | |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 | | | | | |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 | | | | | |
| 10 | 116 | 154 | 204 | 262 | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HEALTH CLUBS, SPAS, YMCA/YWCA, AND COUNTRY CLUBS

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|---------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 8.2 | 1 | | | | 12.3 | 2 | | | | 16.4 | 2 | | | |
| 50 | 11.1 | 1 | | | | 16.7 | 2 | | | | 22.2 | 2 | | | |
| 100 | 15.4 | | 1 | | | 23.1 | 2 | | | | 30.8 | | 2 | | |
| 150 | 19.5 | | | 1 | | 29.3 | | 2 | | | 39.0 | | | 2 | |
| 200 | 22.1 | | | | 1 | 33.2 | | | 2 | | 44.2 | | | | 2 |
| 250 | 23.1 | | | | 1 | 34.7 | | | 2 | | 46.2 | | | | 2 |
| 300 | 24.6 | | | | 1 | 36.9 | | | 2 | | 49.2 | | | | 2 |
| 350 | 25.6 | | | | 1 | 38.4 | | | 2 | | 51.2 | | | | 2 |
| 400 | 27.2 | | 2 | | | 40.8 | | | 2 | | 54.5 | | | 3 | |
| 550 | 32.9 | | | 2 | | 49.4 | | | | 2 | 65.8 | | | | 3 |
| 700 | 37.7 | | | 2 | | 56.6 | | | 3 | | 75.4 | | | | 3 |
| 1000 | 45.9 | | | | 2 | 68.9 | | | | 3 | 91.8 | | | | 4 |
| 1200 | 50.6 | | | | 2 | 75.9 | | | | 3 | 101.2 | | | | 4 |
| 1500 | 56.7 | | | 3 | | 85.1 | | | | 4 | 113.4 | | | | 5 |
| 1800 | 60.3 | | | 3 | | 90.5 | | | | 4 | 120.6 | | | | 5 |
| 2200 | 67.5 | | | | 3 | 101.3 | | | | 4 | 131.0 | | | | 5* |
| 3000 | 85.1 | | | | 4 | 127.7 | | | | 5 | 157.2 | | | | 6* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES: * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



PRISONS AND CORRECTIONAL FACILITIES

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutli | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 15.2 | | 1 | | | 22.8 | 2 | | | | 30.4 | | 2 | | |
| 50 | 19.8 | | | 1 | | 29.7 | | 2 | | | 39.6 | | | 2 | |
| 100 | 27.2 | | 2 | | | 40.8 | | | 2 | | 54.4 | | | 3 | |
| 150 | 30.6 | | 2 | | | 45.9 | | | | 2 | 61.2 | | | 3 | |
| 200 | 35.0 | | | 2 | | 52.4 | | | | 2 | 69.9 | | | | 3 |
| 250 | 38.0 | | | 2 | | 57.0 | | | 3 | | 76.0 | | | | 3 |
| 300 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 4 | |
| 350 | 44.0 | | | | 2 | 66.0 | | | | 3 | 88.0 | | | | 4 |
| 400 | 47.3 | | | | 2 | 71.0 | | | | 3 | 94.7 | | | | 4 |
| 550 | 54.1 | | | 3 | | 81.1 | | | 4 | | 108.2 | | | | 5 |
| 700 | 61.2 | | | 3 | | 91.8 | | | | 4 | 122.4 | | | | 5 |
| 1000 | 77.1 | | | | 3 | 104.8 | | | | 4* | 131.0 | | | | 5* |
| 1200 | 85.1 | | | | 4 | 127.7 | | | | 5 | 157.2 | | | | 6* |
| 1500 | 95.8 | | | | 4 | 131.0 | | | | 5* | 157.2 | | | | 6* |
| 1800 | 111.6 | | | | 5 | 157.2 | | | | 6* | 183.4 | | | | 7* |
| 2200 | 122.4 | | | | 5 | 157.2 | | | | 6* | 183.4 | | | | 7* |
| 3000 | 157.2 | | | | 6 | 183.4 | | | | 7* | 209.6 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES: * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



OFFICE, COMMERCIAL, RETAIL

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | Desigi | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 6.6 | 1 | | | | 9.8 | 2 | | | | 13.1 | 2 | | | |
| 50 | 8.9 | 1 | | | | 13.3 | 2 | | | | 17.8 | 2 | | | |
| 100 | 12.7 | | 1 | | | 19.1 | 2 | | | | 25.4 | | 2 | | |
| 150 | 15.4 | | 1 | | | 23.1 | 2 | | | | 30.8 | | 2 | | |
| 200 | 17.7 | | | 1 | | 26.5 | | 2 | | | 35.4 | | | 2 | |
| 250 | 18.9 | | | 1 | | 28.3 | | 2 | | | 37.8 | | | 2 | |
| 300 | 19.7 | | | 1 | | 29.5 | | 2 | | | 39.4 | | | 2 | |
| 350 | 20.4 | | | 1 | | 30.6 | | 2 | | | 40.8 | | | 2 | |
| 400 | 22.0 | | | | 1 | 33.0 | | | 2 | | 44.0 | | | | 2 |
| 550 | 26.2 | | | | 1 | 39.3 | | | 2 | | 52.4 | | | | 2 |
| 700 | 30.2 | | 2 | | | 45.2 | | | | 2 | 60.3 | | | 3 | |
| 1000 | 36.7 | | | 2 | | 55.1 | | | 3 | | 73.4 | | | | 3 |
| 1200 | 39.3 | | | 2 | | 59.0 | | | 3 | | 78.6 | | | | 3 |
| 1500 | 45.4 | | | | 2 | 68.0 | · | | · | 3 | 90.7 | | · | | 4 |
| 1800 | 48.2 | | | | 2 | 72.4 | | | | 3 | 96.5 | | | | 4 |
| 2200 | 52.4 | | | | 2 | 78.6 | | | | 3 | 104.8 | | | | 4 |
| 3000 | 68.0 | | | | 3 | 102.0 | · | | · | 4 | 131.0 | | · | | 5* |

| Maxim | num Unit Cap | m Unit Capacity (GPM), 40-140 °F INN600 INN800 INN1060 INN1350 11.6 15.4 20.4 26.2 23.2 30.8 40.8 52.4 34.8 46.2 61.2 78.6 46.4 61.6 81.6 104.8 58 77 102 131 69.6 92.4 122.4 157.2 81.2 107.8 142.8 183.4 92.8 123.2 163.2 209.6 | | | | | | | | |
|---------|--------------|--|---------|---------|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 | | | | | | |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 | | | | | | |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 | | | | | | |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 | | | | | | |
| 5 | 58 | 77 | 102 | 131 | | | | | | |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 | | | | | | |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 | | | | | | |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 | | | | | | |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 | | | | | | |
| 10 | 116 | 154 | 204 | 262 | | | | | | |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



INDUSTRIAL PLANT

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | า Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 6.6 | 1 | | | | 9.8 | 2 | | | | 13.1 | 2 | | | |
| 50 | 8.9 | 1 | | | | 13.3 | 2 | | | | 17.8 | 2 | | | |
| 100 | 12.7 | | 1 | | | 19.1 | 2 | | | | 25.4 | | 2 | | |
| 150 | 15.4 | | 1 | | | 23.1 | 2 | | | | 30.8 | | 2 | | |
| 200 | 17.7 | | | 1 | | 26.5 | | 2 | | | 35.4 | | | 2 | |
| 250 | 18.9 | | | 1 | | 28.3 | | 2 | | | 37.8 | | | 2 | |
| 300 | 19.7 | | | 1 | | 29.5 | | 2 | | | 39.4 | | | 2 | |
| 350 | 20.4 | | | 1 | | 30.6 | | 2 | | | 40.8 | | | 2 | |
| 400 | 22.0 | | | | 1 | 33.0 | | | 2 | | 44.0 | | | | 2 |
| 550 | 26.2 | | | | 1 | 39.3 | | | 2 | | 52.4 | | | | 2 |
| 700 | 30.2 | | 2 | | | 45.2 | | | | 2 | 60.3 | | | 3 | |
| 1000 | 36.7 | | | 2 | | 55.1 | | | 3 | | 73.4 | | | | 3 |
| 1200 | 39.3 | | | 2 | | 59.0 | | | 3 | | 78.6 | | | | 3 |
| 1500 | 45.4 | · | · | | 2 | 68.0 | | | · | 3 | 90.7 | | | | 4 |
| 1800 | 48.2 | | | | 2 | 72.4 | | | · | 3 | 96.5 | | | | 4 |
| 2200 | 52.4 | | | | 2 | 78.6 | | | · | 3 | 104.8 | | | | 4 |
| 3000 | 68.0 | | | | 3 | 102.0 | | | | 4 | 131.0 | | | | 5* |

| Maxim | num Unit Cap | acity (GPI | M), 40-14 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 |
| 5 | 58 | 77 | 102 | 131 |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 |
| 10 | 116 | 154 | 204 | 262 |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.
- ****If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.



RESTAURANT

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigi | n Load | 200% Design | Multi | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 5 | 15.3 | | 1 | | | 22.9 | 2 | | | | 30.5 | | 2 | | |
| 15 | 19.9 | | | 1 | | 29.8 | | 2 | | | 39.8 | | | 2 | |
| 25 | 23.2 | | | | 1 | 34.9 | | | 2 | | 46.5 | | | | 2 |
| 50 | 30.6 | | 2 | | | 45.9 | | | | 2 | 61.2 | | | 3 | |
| 75 | 37.5 | | | 2 | | 56.3 | | | 3 | | 75.0 | | | | 3 |
| 100 | 40.8 | | | 2 | | 61.2 | | | 3 | | 81.6 | | | 3 | |
| 150 | 47.9 | | | | 2 | 71.9 | | | | 3 | 95.9 | | | | 4 |
| 200 | 52.4 | | | | 2 | 78.6 | | | | 3 | 104.8 | | | | 4 |
| 250 | 58.5 | | | 3 | | 87.8 | | | | 4 | 117.0 | | | | 5 |
| 300 | 61.2 | | | 3 | | 91.8 | | | | 4 | 122.4 | | | | 5 |
| 350 | 66.5 | | | | 3 | 99.7 | | | | 4 | 131.0 | | | | 5* |
| 400 | 69.9 | | | | 3 | 104.8 | | | | 4 | 131.0 | | | | 5* |
| 550 | 89.7 | | | | 4 | 131.0 | | | | 5* | 122.4 | | | | 6* |
| 700 | 104.3 | · | | | 4 | 131.0 | · | | | 5* | 142.8 | | | | 6* |
| 900 | 122.0 | · | | | 5 | 157.2 | · | | | 6* | 183.4 | | | | 7* |
| 1100 | 138.0 | · | | | 6 | 183.4 | · | | | 7* | 209.6 | | | | 8* |
| 1500 | 166.1 | | | | 7 | 209.6 | | | | 8* | 235.8 | | | | 9* |

| Maxim | Maximum Unit Capacity (GPM), 40-140 °F | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 | | | | | | | |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 | | | | | | | |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 | | | | | | | |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 | | | | | | | |
| 5 | 58 | 77 | 102 | 131 | | | | | | | |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 | | | | | | | |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 | | | | | | | |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 | | | | | | | |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 | | | | | | | |
| 10 | 116 | 154 | 204 | 262 | | | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



GROUP SHOWER LOAD: GYMNASIUM, FIELD HOUSE, SPORTS ARENA, STADIUM, MILITARY BARRACKS, AND PRISONS

Domestic Water Inlet - Outlet Conditions: 40-140 °F

| Shower | Design Load | | Desig | n Load | | Design Load | W/N+1 Ex | cess Capa | city | Stratified Storage Tank (GAL.) | | | |
|--------|-------------|--------|--------|---------|---------|-------------|----------|-----------|---------|--------------------------------|-----|-----|--|
| Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | INN600 | INN800 | INN1060 | INN1350 | 210 | 340 | 505 | |
| 5 | 8.8 | 1 | | | | 2 | | | | | | | |
| 10 | 17.5 | | | 1 | | | | 2 | | | | | |
| 15 | 26.3 | | 2 | | | | 3 | | | | | | |
| 20 | 35.0 | | | 2 | | | | 3 | | | | | |
| 25 | 43.8 | | | | 2 | | | | 3 | | | | |
| 30 | 52.4 | | | | 2 | | | | 3 | | | | |
| 40 | 70.0 | | | | 2 | | | | 3 | | | 1 | |
| 50 | 87.5 | | | 3 | | | | 4 | | | | 1 | |
| 60 | 105.0 | | | | 3 | | | | 4 | | | 1 | |

| Maxim | Maximum Unit Capacity (GPM), 40-140 °F | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | |
| 1 | 11.6 | 15.4 | 20.4 | 26.2 | | | | | | | |
| 2 | 23.2 | 30.8 | 40.8 | 52.4 | | | | | | | |
| 3 | 34.8 | 46.2 | 61.2 | 78.6 | | | | | | | |
| 4 | 46.4 | 61.6 | 81.6 | 104.8 | | | | | | | |
| 5 | 58 | 77 | 102 | 131 | | | | | | | |
| 6 | 69.6 | 92.4 | 122.4 | 157.2 | | | | | | | |
| 7 | 81.2 | 107.8 | 142.8 | 183.4 | | | | | | | |
| 8 | 92.8 | 123.2 | 163.2 | 209.6 | | | | | | | |
| 9 | 104.4 | 138.6 | 183.6 | 235.8 | | | | | | | |
| 10 | 116 | 154 | 204 | 262 | | | | | | | |

NOTES:

- * This sizing is based on 2.5 GPM shower heads, 110°F fixture outlet temperature, all showers are on full for 15 minutes, and the tank recovery time (when employed) can be up to 20 minutes.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HOTELS/MOTELS - MIXED OCCUPANCY

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| | ater fillet - Ot | tict cond | | | | | | 1 0 15 | 00/ D : | | | | 1 0 20 | 00/ 5 : | |
|------------|------------------|-----------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Fixture | Design Load | | Desigi | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | 1 Load |
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 11.3 | 1 | | | | 16.9 | 2 | | | | 22.5 | 2 | | | |
| 50 | 14.7 | | 1 | | | 22.0 | 2 | | | | 29.3 | | 2 | | |
| 100 | 20.2 | | | 1 | | 30.4 | | 2 | | | 40.5 | | | 2 | |
| 150 | 22.5 | | | 1 | | 33.8 | | 2 | | | 45.0 | | | 2 | |
| 200 | 25.6 | | | | 1 | 38.4 | | | 2 | | 51.2 | | | | 2 |
| 250 | 28.1 | | | | 1 | 42.2 | | | 2 | | 56.2 | | | | 2 |
| 300 | 30.2 | | 2 | | | 45.4 | | | 2 | | 60.5 | | | 3 | |
| 350 | 32.6 | | 2 | | | 48.9 | | | | 2 | 65.1 | | | 3 | |
| 400 | 34.2 | | 2 | | | 51.2 | | | | 2 | 68.1 | | | 3 | |
| 550 | 40.0 | | | 2 | | 60.0 | | | 3 | | 80.1 | | | | 3 |
| 700 | 45.1 | | | 2 | | 67.6 | | | 3 | | 90.1 | | | 4 | |
| 1000 | 56.1 | | | | 2 | 84.2 | | | | 3 | 112.2 | | | | 4 |
| 1200 | 63.0 | | | 3 | | 94.5 | | | | 4 | 126.0 | | | | 5 |
| 1500 | 70.9 | | | | 3 | 106.3 | | | | 4 | 141.7 | | | | 5 |
| 1800 | 82.6 | · | | | 3 | 116.4 | · | | | 4* | 145.5 | | | | 5* |
| 2200 | 87.3 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 3000 | 113.4 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |

| Maxim | Maximum Unit Capacity (GPM), 40-130 °F | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 | | | | | | | |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 | | | | | | | |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 | | | | | | | |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 | | | | | | | |
| 5 | 64 | 85.5 | 113.5 | 145.5 | | | | | | | |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 | | | | | | | |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 | | | | | | | |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 | | | | | | | |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 | | | | | | | |
| 10 | 128 | 171 | 227 | 291 | | | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HOTELS/MOTELS - CONVENTION CENTER/BUSINESS MEETING

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| | ater inlet - Ou | itiet Conu | | | | | | | | | | | | | |
|-------------------|-----------------|------------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Fixture | Design Load | | Desigi | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 15.9 | | 1 | | | 23.9 | 2 | | | | 31.9 | | 2 | | |
| 50 | 20.8 | | | 1 | | 31.1 | | 2 | | | 41.5 | | | 2 | |
| 100 | 28.7 | | 2 | | | 43.0 | | | 2 | | 57.4 | | | | 2 |
| 150 | 33.6 | | 2 | | | 50.4 | | | | 2 | 67.2 | | | 3 | |
| 200 | 36.9 | | | 2 | | 55.3 | | | | 2 | 73.8 | | | | 3 |
| 250 | 39.8 | | | 2 | | 59.7 | | | 3 | | 79.6 | | | | 3 |
| 300 | 42.8 | | | 2 | | 64.3 | | | 3 | | 85.7 | | | | 3 |
| 350 | 45.3 | | | 2 | | 67.9 | | | 3 | | 90.5 | | | 4 | |
| 400 | 49.6 | | | | 2 | 74.4 | | | | 3 | 99.3 | | | | 4 |
| 550 | 56.7 | | | | 2 | 85.1 | | | | 3 | 113.4 | | | | 4 |
| 700 | 66.0 | | | 3 | | 99.1 | | | | 4 | 132.1 | | | | 5 |
| 1000 | 80.9 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1200 | 87.3 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1500 | 100.4 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 1800 | 116.3 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 2200 | 132.1 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 3000 | 159.1 | | | | 6 | 203.7 | | | | 7* | 232.8 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



APARTMENT COMPLEXES/CONDOMINIUMS

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 9.5 | 1 | | | | 14.3 | 2 | | | | 19.0 | 2 | | | |
| 50 | 12.6 | 1 | | | | 18.9 | 2 | | | | 25.3 | 2 | | | |
| 100 | 16.7 | | 1 | | | 25.1 | 2 | | | | 33.5 | | 2 | | |
| 150 | 20.0 | | | 1 | | 30.0 | | 2 | | | 40.0 | | | 2 | |
| 200 | 22.3 | | | 1 | | 33.4 | | 2 | | | 44.6 | | | 2 | |
| 250 | 24.2 | | | | 1 | 36.4 | | | 2 | | 48.5 | | | | 2 |
| 300 | 25.5 | | | | 1 | 38.3 | | | 2 | | 51.1 | | | | 2 |
| 350 | 27.7 | | | | 1 | 41.6 | | | 2 | | 55.4 | | | | 2 |
| 400 | 29.9 | | 2 | | | 44.8 | | | 2 | | 59.7 | | | 3 | |
| 550 | 35.7 | | | 2 | | 53.6 | | | | 2 | 71.4 | | | | 3 |
| 700 | 40.8 | | | 2 | | 61.3 | | | 3 | | 81.7 | | | | 3 |
| 1000 | 45.4 | | | 2 | | 68.1 | | | 3 | | 90.8 | | | 4 | |
| 1200 | 53.1 | | | | 2 | 79.7 | | | | 3 | 106.2 | | | | 4 |
| 1500 | 59.4 | | | | 2 | 89.1 | | | | 3 | 118.8 | | | | 4 |
| 1800 | 64.9 | | | 3 | | 97.4 | · | · | | 4 | 129.9 | | | | 5 |
| 2200 | 72.0 | | | | 3 | 108.0 | | | | 4 | 144.0 | | | | 5 |
| 3000 | 93.7 | · | | | 4 | 140.5 | · | · | | 5 | 174.6 | | | | 6* |

| Maxim | Maximum Unit Capacity (GPM), 40-130 °F | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 | | | | | | | |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 | | | | | | | |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 | | | | | | | |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 | | | | | | | |
| 5 | 64 | 85.5 | 113.5 | 145.5 | | | | | | | |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 | | | | | | | |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 | | | | | | | |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 | | | | | | | |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 | | | | | | | |
| 10 | 128 | 171 | 227 | 291 | | | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



NURSING HOMES, ASSISTED LIVING

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 15.9 | | 1 | | | 23.9 | 2 | | | | 31.9 | | 2 | | |
| 50 | 20.8 | | | 1 | | 31.1 | | 2 | | | 41.5 | | | 2 | |
| 100 | 28.7 | | 2 | | | 43.0 | | | 2 | | 57.4 | | | | 2 |
| 150 | 33.6 | | 2 | | | 50.4 | | | | 2 | 67.2 | | | 3 | |
| 200 | 36.9 | | | 2 | | 55.3 | | | | 2 | 73.8 | | | | 3 |
| 250 | 39.8 | | | 2 | | 59.7 | | | 3 | | 79.6 | | | | 3 |
| 300 | 42.8 | | | 2 | | 64.3 | | | 3 | | 85.7 | | | | 3 |
| 350 | 45.3 | | | 2 | | 67.9 | | | 3 | | 90.5 | | | 4 | |
| 400 | 49.6 | | | | 2 | 74.4 | | | | 3 | 99.3 | | | | 4 |
| 550 | 56.7 | | | | 2 | 85.1 | | | | 3 | 113.4 | | | | 4 |
| 700 | 66.0 | | | 3 | | 90.8 | | | | 4 | 132.1 | | | | 5 |
| 1000 | 80.9 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1200 | 87.3 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1500 | 100.4 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 1800 | 116.3 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 2200 | 132.1 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 3000 | 159.1 | | | | 6 | 203.7 | | | | 7* | 232.8 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HOSPITALS, MEDICAL FACILITIES, PSYCHIATRIC CENTERS

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 15.9 | | 1 | | | 23.9 | 2 | | | | 31.9 | | 2 | | |
| 50 | 20.8 | | | 1 | | 31.1 | | 2 | | | 41.5 | | | 2 | |
| 100 | 28.7 | | 2 | | | 43.0 | | | 2 | | 57.4 | | | | 2 |
| 150 | 33.6 | | 2 | | | 50.4 | | | | 2 | 67.2 | | | 3 | |
| 200 | 36.9 | | | 2 | | 55.3 | | | | 2 | 73.8 | | | | 3 |
| 250 | 39.8 | | | 2 | | 59.7 | | | 3 | | 79.6 | | | | 3 |
| 300 | 42.8 | | | 2 | | 64.3 | | | 3 | | 85.7 | | | | 3 |
| 350 | 45.3 | | | 2 | | 67.9 | | | 3 | | 90.5 | | | 4 | |
| 400 | 49.6 | | | | 2 | 74.4 | | | | 3 | 99.3 | | | | 4 |
| 550 | 56.7 | | | | 2 | 85.1 | | | | 3 | 113.4 | | | | 4 |
| 700 | 66.0 | | | 3 | | 90.8 | | | | 4 | 132.1 | | | | 5 |
| 1000 | 80.9 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1200 | 87.3 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1500 | 100.4 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 1800 | 116.3 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 2200 | 132.1 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 3000 | 159.1 | | | | 6 | 203.7 | | | | 7* | 232.8 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



SCHOOLS - ELEMENTARY, MIDDLE, HIGH SCHOOLS, AND COLLEGES

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multi | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 8.2 | 1 | | | | 12.3 | 2 | | | | 16.4 | 2 | | | |
| 50 | 11.1 | 1 | | | | 16.6 | 2 | | | | 22.2 | 2 | | | |
| 100 | 15.9 | | 1 | | | 23.8 | 2 | | | | 31.8 | | 2 | | |
| 150 | 19.5 | | | 1 | | 29.2 | | 2 | | | 39.0 | | | 2 | |
| 200 | 22.1 | | | 1 | | 33.1 | | 2 | | | 44.2 | | | 2 | |
| 250 | 23.6 | | | | 1 | 35.4 | | | 2 | | 47.2 | | | | 2 |
| 300 | 24.6 | | | | 1 | 36.9 | | | 2 | | 49.2 | | | | 2 |
| 350 | 25.6 | | | | 1 | 38.4 | | | 2 | | 51.1 | | | | 2 |
| 400 | 27.5 | | | | 1 | 41.2 | | | 2 | | 54.9 | | | | 2 |
| 550 | 32.9 | | 2 | | | 49.3 | | | | 2 | 65.7 | | | 3 | |
| 700 | 37.7 | | | 2 | | 56.5 | | | | 2 | 75.3 | | | | 3 |
| 1000 | 45.1 | | | 2 | | 67.6 | | | 3 | | 90.2 | | | | 4 |
| 1200 | 49.7 | | | | 2 | 74.6 | | | | 3 | 99.4 | | | | 4 |
| 1500 | 55.7 | | | | 2 | 83.5 | | | | 3 | 111.4 | | | | 4 |
| 1800 | 59.2 | | | | 3 | 88.9 | | | | 4 | 118.5 | | | | 5 |
| 2200 | 66.3 | | | | 3 | 99.5 | | | | 4 | 132.6 | | | | 5 |
| 3000 | 83.6 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart



UNIVERSITY/COLLEGE DORMITORIES

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 16.9 | | 1 | | | 25.3 | 2 | | | | 33.8 | | 2 | | |
| 50 | 22.0 | | | 1 | | 33.0 | | 2 | | | 44.0 | | | 2 | |
| 100 | 30.2 | | 2 | | | 45.3 | | | 2 | | 60.4 | | | 3 | |
| 150 | 34.0 | | 2 | | | 51.0 | | | | 2 | 68.0 | | | 3 | |
| 200 | 39.1 | | | 2 | | 58.6 | | | | 2 | 78.1 | | | | 3 |
| 250 | 42.2 | | | 2 | | 63.2 | | | 3 | | 84.3 | | | | 3 |
| 300 | 45.4 | | | 2 | | 68.0 | | | 3 | | 90.7 | | | 4 | |
| 350 | 48.9 | | | | 2 | 73.3 | | | | 3 | 97.7 | | | | 4 |
| 400 | 51.1 | | | | 2 | 76.6 | | | | 3 | 102.2 | | | | 4 |
| 550 | 60.0 | | | 3 | | 90.1 | | | 4 | | 120.1 | | | | 5 |
| 700 | 68.1 | | | 3 | | 102.2 | | | | 4 | 136.3 | | | | 5 |
| 1000 | 85.6 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1200 | 94.5 | | | | 4 | 141.8 | | | | 5 | 174.6 | | | | 6* |
| 1500 | 106.3 | | | | 4 | 145.5 | | | · | 5* | 174.6 | | · | | 6* |
| 1800 | 123.9 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 2200 | 135.8 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 3000 | 174.6 | | | | 6 | 203.7 | | | | 7* | 232.8 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HEALTH CLUBS, SPAS, YMCA/YWCA, AND COUNTRY CLUBS

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| | Desire Lead | tiet cond | | | | | N 4 11' | 1045 | 00/ D | | | N 4 11. | .1 0.20 | 00/ D | |
|------------|-------------|-----------|--------|---------|---------|-------------|---------|-----------|-----------|---------|-------------|---------|-----------|-----------|---------|
| Fixture | Design Load | | Design | ո Load | | 150% Design | Mutlip | oles @ 15 | u% Desigr | i Load | 200% Design | Multi | oies @ 20 | 0% Desigr | 1 Load |
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 9.1 | 1 | | | | 13.7 | 2 | | | | 18.2 | 2 | | | |
| 50 | 12.3 | 1 | | | | 18.5 | 2 | | | | 24.6 | 2 | | | |
| 100 | 17.0 | | 1 | | | 25.5 | 2 | | | | 34.1 | | 2 | | |
| 150 | 21.6 | | | 1 | | 32.5 | | 2 | | | 43.3 | | | 2 | |
| 200 | 24.5 | | | | 1 | 36.8 | | | 2 | | 49.1 | | | | 2 |
| 250 | 25.6 | | | | 1 | 38.4 | | | 2 | | 51.2 | | | | 2 |
| 300 | 27.3 | | | | 1 | 41.0 | | | 2 | | 54.6 | | | | 2 |
| 350 | 28.4 | | | | 1 | 42.6 | | | 2 | | 56.8 | | | | 2 |
| 400 | 30.2 | | 2 | | | 45.3 | | | 2 | | 60.4 | | | 3 | |
| 550 | 36.5 | | | 2 | | 54.8 | | | | 2 | 73.0 | | | | 3 |
| 700 | 41.8 | | | 2 | | 62.8 | | | 3 | | 83.7 | | | | 3 |
| 1000 | 50.9 | | | | 2 | 76.4 | | | | 3 | 101.9 | | | | 4 |
| 1200 | 56.2 | | | | 2 | 84.2 | | | | 3 | 112.3 | | | | 4 |
| 1500 | 62.9 | | | 3 | | 94.4 | | | | 4 | 125.9 | | | | 5 |
| 1800 | 66.9 | | | 3 | | 100.4 | · | | | 4 | 133.9 | | | | 5 |
| 2200 | 74.9 | | | | 3 | 112.4 | | | | 4 | 145.5 | | | | 5* |
| 3000 | 90.8 | | | | 4 | 136.2 | · | | | 5 | 174.6 | | | | 6* |

| Maxim | Maximum Unit Capacity (GPM), 40-130 °F | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 | | | | | | | | |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 | | | | | | | | |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 | | | | | | | | |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 | | | | | | | | |
| 5 | 64 | 85.5 | 113.5 | 145.5 | | | | | | | | |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 | | | | | | | | |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 | | | | | | | | |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 | | | | | | | | |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 | | | | | | | | |
| 10 | 128 | 171 | 227 | 291 | | | | | | | | |

NOTES: * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



PRISONS AND CORRECTIONAL FACILITIES

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlin | oles @ 15 | 0% Design | n Load | 200% Design | Multir | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|--------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | _ | INN600 | INN800 | | INN1350 | _ | INN600 | | | INN1350 | Load (GPM) | INN600 | | | INN1350 |
| 25 | 16.9 | | 1 | | | 25.3 | 2 | | | | 33.8 | | 2 | | |
| 50 | 22.0 | | | 1 | | 33.0 | | 2 | | | 44.0 | | | 2 | |
| 100 | 30.2 | | 2 | | | 45.3 | | | 2 | | 60.4 | | | 3 | |
| 150 | 34.0 | | 2 | | | 51.0 | | | | 2 | 68.0 | | | 3 | |
| 200 | 39.1 | | | 2 | | 58.6 | | | | 2 | 78.1 | | | | 3 |
| 250 | 42.2 | | | 2 | | 63.2 | | | 3 | | 84.3 | | | | 3 |
| 300 | 45.4 | | | 2 | | 68.0 | | | 3 | | 90.7 | | | 4 | |
| 350 | 48.9 | | | | 2 | 73.3 | | | | 3 | 97.7 | | | | 4 |
| 400 | 51.1 | | | | 2 | 76.6 | | | | 3 | 102.2 | | | | 4 |
| 550 | 60.0 | | | 3 | | 90.1 | | | 4 | | 120.1 | | | | 5 |
| 700 | 68.1 | | | 3 | | 102.2 | | | | 4 | 136.3 | | | | 5 |
| 1000 | 85.6 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 1200 | 94.5 | | | | 4 | 141.8 | | | | 5 | 174.6 | | | | 6* |
| 1500 | 106.3 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 1800 | 123.9 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 2200 | 135.8 | | | | 5 | 174.6 | | | | 6* | 203.7 | | | | 7* |
| 3000 | 174.6 | | | | 6 | 203.7 | | | | 7* | 232.8 | | | | 8* |

| Maxim | Maximum Unit Capacity (GPM), 40-130 °F | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 | | | | | | | | |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 | | | | | | | | |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 | | | | | | | | |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 | | | | | | | | |
| 5 | 64 | 85.5 | 113.5 | 145.5 | | | | | | | | |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 | | | | | | | | |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 | | | | | | | | |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 | | | | | | | | |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 | | | | | | | | |
| 10 | 128 | 171 | 227 | 291 | | | | | | | | |

NOTES: * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



OFFICE, COMMERCIAL, RETAIL

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 7.3 | 1 | | | | 10.9 | 2 | | | | 14.6 | 2 | | | |
| 50 | 9.9 | 1 | | | | 14.8 | 2 | | | | 19.7 | 2 | | | |
| 100 | 14.1 | | 1 | | | 21.2 | 2 | | | | 28.2 | | 2 | | |
| 150 | 17.1 | | 1 | | | 25.6 | 2 | | | | 34.2 | | 2 | | |
| 200 | 19.6 | | | 1 | | 29.4 | | 2 | | | 39.2 | | | 2 | |
| 250 | 21.0 | | | 1 | | 31.4 | | 2 | | | 41.9 | | | 2 | |
| 300 | 21.8 | | | 1 | | 32.8 | | 2 | | | 43.7 | | | 2 | |
| 350 | 22.7 | | | 1 | | 34.1 | | 2 | | | 45.5 | | | 2 | |
| 400 | 24.4 | | | | 1 | 36.6 | | | 2 | | 48.8 | | | | 2 |
| 550 | 29.2 | | | | 1 | 43.8 | | | 2 | | 58.4 | | | | 2 |
| 700 | 33.5 | | 2 | | | 50.2 | | | | 2 | 67.0 | | | 3 | |
| 1000 | 40.8 | | | 2 | | 61.1 | | | 3 | | 81.5 | | | | 3 |
| 1200 | 44.9 | | | 2 | | 67.4 | | | 3 | | 89.9 | | | | 3 |
| 1500 | 50.3 | | | · | 2 | 75.5 | · | | · | 3 | 100.7 | | | | 4 |
| 1800 | 53.5 | | | | 2 | 80.3 | | | | 3 | 107.1 | | | | 4 |
| 2200 | 59.9 | | | | 2 | 89.9 | | | | 3 | 116.4 | | | | 4* |
| 3000 | 75.6 | | | · | 3 | 113.4 | · | | · | 4 | 145.5 | | | | 5* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



INDUSTRIAL PLANT

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | • | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 7.3 | 1 | | | | 10.9 | 2 | | | | 14.6 | 2 | | | |
| 50 | 9.9 | 1 | | | | 14.8 | 2 | | | | 19.7 | 2 | | | |
| 100 | 14.1 | | 1 | | | 21.2 | 2 | | | | 28.2 | | 2 | | |
| 150 | 17.1 | | 1 | | | 25.6 | 2 | | | | 34.2 | | 2 | | |
| 200 | 19.6 | | | 1 | | 29.4 | | 2 | | | 39.2 | | | 2 | |
| 250 | 21.0 | | | 1 | | 31.4 | | 2 | | | 41.9 | | | 2 | |
| 300 | 21.8 | | | 1 | | 32.8 | | 2 | | | 43.7 | | | 2 | |
| 350 | 22.7 | | | 1 | | 34.1 | | 2 | | | 45.5 | | | 2 | |
| 400 | 24.4 | | | | 1 | 36.6 | | | 2 | | 48.8 | | | | 2 |
| 550 | 29.2 | | | | 1 | 43.8 | | | 2 | | 58.4 | | | | 2 |
| 700 | 33.5 | | 2 | | | 50.2 | | | | 2 | 67.0 | | | 3 | |
| 1000 | 40.8 | | | 2 | | 61.1 | | | 3 | | 81.5 | | | | 3 |
| 1200 | 44.9 | | | 2 | | 67.4 | | | 3 | | 89.9 | | | | 3 |
| 1500 | 50.3 | | | | 2 | 75.5 | | | | 3 | 100.7 | | | | 4 |
| 1800 | 53.5 | | | | 2 | 80.3 | | | | 3 | 107.1 | | | | 4 |
| 2200 | 59.9 | | | | 2 | 89.9 | | | | 3 | 116.4 | | | | 4* |
| 3000 | 75.6 | | | | 3 | 113.4 | | | | 4 | 145.5 | | | | 5* |

| Maxim | Maximum Unit Capacity (GPM), 40-130 °F | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 | | | | | | | | |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 | | | | | | | | |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 | | | | | | | | |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 | | | | | | | | |
| 5 | 64 | 85.5 | 113.5 | 145.5 | | | | | | | | |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 | | | | | | | | |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 | | | | | | | | |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 | | | | | | | | |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 | | | | | | | | |
| 10 | 128 | 171 | 227 | 291 | | | | | | | | |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.
- ****If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.



RESTAURANT

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 5 | 17.1 | | 1 | | | 25.6 | 2 | | | | 34.0 | | 2 | | |
| 15 | 22.1 | | | 1 | | 33.1 | | 2 | | | 44.1 | | | 2 | |
| 25 | 25.6 | | | | 1 | 38.4 | | | 2 | | 51.2 | | | | 2 |
| 50 | 34.2 | | 2 | | | 51.3 | | | | 2 | 68.4 | | | 3 | |
| 75 | 41.6 | | | 2 | | 62.4 | | | 3 | | 83.3 | | | | 3 |
| 100 | 45.3 | | | 2 | | 67.9 | | | 3 | | 90.6 | | | 3 | |
| 150 | 53.2 | | | | 2 | 79.8 | | | | 3 | 106.4 | | | | 4 |
| 200 | 59.0 | | | | 2 | 88.5 | | | | 3 | 118.0 | | | | 4 |
| 250 | 64.9 | | | 3 | | 97.4 | | | | 4 | 129.9 | | | | 5 |
| 300 | 68.0 | | | 3 | | 102.0 | | | | 4 | 136.0 | | | | 5 |
| 350 | 73.8 | | | | 3 | 110.6 | | | | 4 | 145.5 | | | | 5* |
| 400 | 79.2 | | | | 3 | 116.4 | | | | 4* | 145.5 | | | | 5* |
| 550 | 99.6 | | | | 4 | 145.5 | | | | 5* | 174.6 | | | | 6* |
| 700 | 115.8 | | | | 4 | 145.5 | · | | | 5* | 174.6 | · | | | 6* |
| 900 | 135.4 | | | | 5 | 174.6 | · | | | 6* | 203.7 | · | | | 7* |
| 1100 | 153.2 | | | | 6 | 203.7 | | | | 7* | 232.8 | | | | 8* |
| 1500 | 184.3 | | | | 7 | 232.8 | | | | 8* | 227.0 | | | | 9* |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0°F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



GROUP SHOWER LOAD: GYMNASIUM, FIELD HOUSE, SPORTS ARENA, STADIUM, MILITARY BARRACKS, AND PRISONS

Domestic Water Inlet - Outlet Conditions: 40-130 °F

| Shower | Design Load | | | n Load | | Design Load | W/N+1 Ex | cess Capa | city |
|--------|-------------|--------|--------|---------|---------|-------------|----------|-----------|---------|
| Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | INN600 | INN800 | INN1060 | INN1350 |
| 5 | 9.7 | 1 | | | | 2 | | | |
| 10 | 19.4 | | | 1 | | | | 2 | |
| 15 | 29.2 | | 2 | | | | 3 | | |
| 20 | 38.9 | | | 2 | | | | 3 | |
| 25 | 48.6 | | | | 2 | | | | 3 |
| 30 | 58.2 | | | | 2 | | | | 3 |
| 35 | 67.9 | | | 3 | | | | 4 | |
| 40 | 77.6 | | | | 3 | | | | 4 |
| 45 | 87.3 | | | | 3 | | | | 4 |

| Maxim | num Unit Cap | acity (GPI | M), 40-13 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 12.8 | 17.1 | 22.7 | 29.1 |
| 2 | 25.6 | 34.2 | 45.4 | 58.2 |
| 3 | 38.4 | 51.3 | 68.1 | 87.3 |
| 4 | 51.2 | 68.4 | 90.8 | 116.4 |
| 5 | 64 | 85.5 | 113.5 | 145.5 |
| 6 | 76.8 | 102.6 | 136.2 | 174.6 |
| 7 | 89.6 | 119.7 | 158.9 | 203.7 |
| 8 | 102.4 | 136.8 | 181.6 | 232.8 |
| 9 | 115.2 | 153.9 | 204.3 | 261.9 |
| 10 | 128 | 171 | 227 | 291 |

NOTES:

- * This sizing is based on 2.5 GPM shower heads, 110°F fixture outlet temperature, all showers are on full for 15 minutes, and the tank recovery time (when employed) can be up to 20 minutes.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.
- **** When storage tanks are employed, 140 °F is the minimum domestic hot water setpoint. See pg. D300.14 for sizing recommendation above 30 shower heads.



HOTELS/MOTELS - MIXED OCCUPANCY

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 12.7 | 1 | | | | 19.0 | 2 | | | | 25.4 | 2 | | | |
| 50 | 16.5 | | 1 | | | 24.8 | 2 | | | | 33.0 | | 2 | | |
| 100 | 22.8 | | | 1 | | 34.2 | | 2 | | | 45.6 | | | 2 | |
| 150 | 25.4 | | | 1 | | 38.0 | | 2 | | | 50.7 | | | 2 | |
| 200 | 28.8 | | | | 1 | 43.3 | | | 2 | | 57.7 | | | | 2 |
| 250 | 31.7 | | | | 1 | 47.5 | | | 2 | | 63.3 | | | | 2 |
| 300 | 34.1 | | 2 | | | 51.1 | | | 2 | | 68.1 | | | 3 | |
| 350 | 36.7 | | 2 | | | 55.0 | | | | 2 | 73.4 | | | 3 | |
| 400 | 38.5 | | 2 | | | 57.7 | | | | 2 | 76.9 | | | 3 | |
| 550 | 45.1 | | | 2 | | 67.6 | | | 3 | | 90.2 | | | | 3 |
| 700 | 50.8 | | | 2 | | 76.1 | | | 3 | | 101.5 | | | 4 | |
| 1000 | 63.2 | | | | 2 | 94.8 | | | | 3 | 126.4 | | | | 4 |
| 1200 | 71.0 | | | 3 | | 106.4 | | | | 4 | 141.9 | | | | 5 |
| 1500 | 79.8 | | | | 3 | 119.7 | | | | 4 | 159.6 | | | | 5 |
| 1800 | 93.0 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 2200 | 105.0 | | | | 4 | 157.5 | | | | 5 | 196.8 | | | | 6* |
| 3000 | 131.2 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HOTELS/MOTELS - CONVENTION CENTER/BUSINESS MEETING

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|--------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | U | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | | INN1060 | |
| 25 | 18.0 | | 1 | | | 26.9 | 2 | | | | 35.9 | | 2 | | |
| 50 | 23.4 | | | 1 | | 35.1 | | 2 | | | 46.8 | | | 2 | |
| 100 | 32.3 | | 2 | | | 48.5 | | | 2 | | 64.6 | | | | 2 |
| 150 | 37.8 | | 2 | | | 56.7 | | | | 2 | 75.7 | | | 3 | |
| 200 | 41.5 | | | 2 | | 62.3 | | | | 2 | 83.1 | | | | 3 |
| 250 | 44.8 | | | 2 | | 67.3 | | | 3 | | 89.7 | | | | 3 |
| 300 | 48.2 | | | 2 | | 72.4 | | | 3 | | 96.5 | | | | 3 |
| 350 | 51.0 | | | 2 | | 76.5 | | | 3 | | 102.0 | | | 4 | |
| 400 | 55.9 | | | | 2 | 83.8 | | | | 3 | 111.8 | | | | 4 |
| 550 | 63.9 | | | | 2 | 95.8 | | | | 3 | 127.7 | | | | 4 |
| 700 | 74.4 | | | 3 | | 111.6 | | | | 4 | 148.8 | | | | 5 |
| 1000 | 91.1 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 1200 | 100.5 | | | | 4 | 128.0 | | | | 5* | 196.8 | | | | 6* |
| 1500 | 113.1 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 1800 | 131.2 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 2200 | 148.8 | | | | 5 | 196.8 | | | | 6* | 229.6 | | | | 7* |
| 3000 | 179.1 | | | | 6 | 229.6 | | | | 7* | 262.4 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0°F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



APARTMENT COMPLEXES/CONDOMINIUMS

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|---|---------|---------|-------------|--------|-----------|-----------|--------|-------------|--------|-----------|-----------|--------|
| Unit Count | _ | INN600 | | INN1060 | INN1350 | _ | INN600 | | ı - | | Load (GPM) | INN600 | | INN1060 | |
| 25 | 10.7 | 1 | | | | 16.1 | 2 | | | | 21.5 | 2 | | | |
| 50 | 14.2 | 1 | | | | 21.3 | 2 | | | | 28.4 | 2 | | | |
| 100 | 18.9 | | 1 | | | 28.3 | 2 | | | | 37.7 | | 2 | | |
| 150 | 22.5 | | | 1 | | 33.8 | | 2 | | | 45.0 | | | 2 | |
| 200 | 25.1 | | | 1 | | 37.7 | | 2 | | | 50.2 | | | 2 | |
| 250 | 27.3 | | | | 1 | 41.0 | | | 2 | | 54.6 | | | | 2 |
| 300 | 28.8 | | | | 1 | 43.1 | | | 2 | | 57.5 | | | | 2 |
| 350 | 31.2 | | | | 1 | 46.8 | | | 2 | | 62.4 | | | | 2 |
| 400 | 33.6 | | 2 | | | 50.5 | | | 2 | | 67.3 | | | 3 | |
| 550 | 40.2 | | | 2 | | 60.3 | | | | 2 | 80.4 | | | | 3 |
| 700 | 46.0 | | | 2 | | 69.0 | | | 3 | | 92.0 | | | | 3 |
| 1000 | 51.2 | | | 2 | | 76.8 | | | 3 | | 102.4 | | | 4 | |
| 1200 | 59.8 | | | | 2 | 89.7 | | | | 3 | 119.6 | | | | 4 |
| 1500 | 65.6 | | | | 2 | 98.4 | | | | 3 | 131.2 | | | | 4 |
| 1800 | 73.1 | | | 3 | | 102.4 | | | | 4 | 146.3 | | | | 5 |
| 2200 | 81.1 | | | | 3 | 121.6 | | | | 4 | 162.2 | | | | 5 |
| 3000 | 105.5 | | | | 4 | 158.2 | | | | 5 | 196.8 | | | | 6* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



NURSING HOMES, ASSISTED LIVING

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multi | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 18.0 | | 1 | | | 26.9 | 2 | | | | 35.9 | | 2 | | |
| 50 | 23.4 | | | 1 | | 35.1 | | 2 | | | 46.8 | | | 2 | |
| 100 | 32.3 | | 2 | | | 48.5 | | | 2 | | 64.6 | | | | 2 |
| 150 | 37.8 | | 2 | | | 56.7 | | | | 2 | 75.7 | | | 3 | |
| 200 | 41.5 | | | 2 | | 62.3 | | | | 2 | 83.1 | | | | 3 |
| 250 | 44.8 | | | 2 | | 67.3 | | | 3 | | 89.7 | | | | 3 |
| 300 | 48.2 | | | 2 | | 72.4 | | | 3 | | 96.5 | | | | 3 |
| 350 | 51.0 | | | 2 | | 76.5 | | | 3 | | 102.0 | | | 4 | |
| 400 | 55.9 | | | | 2 | 83.8 | | | | 3 | 111.8 | | | | 4 |
| 550 | 63.9 | | | | 2 | 95.8 | | | | 3 | 127.7 | | | | 4 |
| 700 | 74.4 | | | 3 | | 111.6 | | | | 4 | 148.8 | | | | 5 |
| 1000 | 91.1 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 1200 | 100.5 | | | | 4 | 128.0 | | | | 5* | 196.8 | | | | 6* |
| 1500 | 113.1 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 1800 | 131.2 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 2200 | 148.8 | | | | 5 | 196.8 | | - | | 6* | 229.6 | - | | | 7* |
| 3000 | 179.1 | | · | | 6 | 229.6 | · | | · | 7* | 262.4 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HOSPITALS, MEDICAL FACILITIES, PSYCHIATRIC CENTERS

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | Design | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | า Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|--|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 18.0 | | 1 | | | 26.9 | 2 | | | | 35.9 | | 2 | | |
| 50 | 23.4 | | | 1 | | 35.1 | | 2 | | | 46.8 | | | 2 | |
| 100 | 32.3 | | 2 | | | 48.5 | | | 2 | | 64.6 | | | | 2 |
| 150 | 37.8 | | 2 | | | 56.7 | | | | 2 | 75.7 | | | 3 | |
| 200 | 41.5 | | | 2 | | 62.3 | | | | 2 | 83.1 | | | | 3 |
| 250 | 44.8 | | | 2 | | 67.3 | | | 3 | | 89.7 | | | | 3 |
| 300 | 48.2 | | | 2 | | 72.4 | | | 3 | | 96.5 | | | | 3 |
| 350 | 51.0 | | | 2 | | 76.5 | | | 3 | | 102.0 | | | 4 | |
| 400 | 55.9 | | | | 2 | 83.8 | | | | 3 | 111.8 | | | | 4 |
| 550 | 63.9 | | | | 2 | 95.8 | | | | 3 | 127.7 | | | | 4 |
| 700 | 74.4 | | | 3 | | 111.6 | | | | 4 | 148.8 | | | | 5 |
| 1000 | 91.1 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 1200 | 100.5 | | | | 4 | 128.0 | | | | 5* | 196.8 | | | | 6* |
| 1500 | 113.1 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 1800 | 131.2 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 2200 | 148.8 | | | | 5 | 196.8 | | | | 6* | 229.6 | | | | 7* |
| 3000 | 179.1 | | | | 6 | 229.6 | | | | 7* | 262.4 | | , and the second | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



SCHOOLS - ELEMENTARY, MIDDLE, HIGH SCHOOLS, AND COLLEGES

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 9.2 | 1 | | | | 13.8 | 2 | | | | 18.5 | 2 | | | |
| 50 | 12.5 | 1 | | | | 18.7 | 2 | | | | 25.0 | 2 | | | |
| 100 | 17.9 | | 1 | | | 26.8 | 2 | | | | 35.8 | | 2 | | |
| 150 | 21.9 | | | 1 | | 32.9 | | 2 | | | 43.9 | | | 2 | |
| 200 | 24.9 | | | 1 | | 37.3 | | 2 | | | 49.7 | | | 2 | |
| 250 | 26.6 | | | | 1 | 39.8 | | | 2 | | 53.1 | | | | 2 |
| 300 | 27.7 | | | | 1 | 41.5 | | | 2 | | 55.4 | | | | 2 |
| 350 | 28.8 | | | | 1 | 43.2 | | | 2 | | 57.6 | | | | 2 |
| 400 | 30.9 | | | | 1 | 46.4 | | | 2 | | 61.9 | | | | 2 |
| 550 | 37.0 | | 2 | | | 55.5 | | | | 2 | 74.0 | | | 3 | |
| 700 | 42.4 | | | 2 | | 63.6 | | | | 2 | 84.8 | | | | 3 |
| 1000 | 51.1 | | | 2 | | 76.6 | | | 3 | | 102.1 | | | | 4 |
| 1200 | 56.9 | | | | 2 | 85.4 | | | | 3 | 113.9 | | | | 4 |
| 1500 | 63.8 | | | | 2 | 95.7 | | | | 3 | 127.6 | | | | 4 |
| 1800 | 67.8 | | | 3 | | 101.8 | | | 4 | | 135.7 | | | | 5 |
| 2200 | 75.9 | | | 3 | | 113.9 | | | | 4 | 151.9 | | | | 5 |
| 3000 | 95.7 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |

| um Unit Cap | acity (CDI | 11 10 10 | | | | | | | | | | |
|--|---|--|---|--|--|--|--|--|--|--|--|--|
| Maximum Unit Capacity (GPM), 40-120 °F | | | | | | | | | | | | |
| INN600 | INN800 | INN1060 | INN1350 | | | | | | | | | |
| 14.5 | 19.3 | 25.6 | 32.8 | | | | | | | | | |
| 29 | 38.6 | 51.2 | 65.6 | | | | | | | | | |
| 43.5 | 57.9 | 76.8 | 98.4 | | | | | | | | | |
| 58 | 77.2 | 102.4 | 131.2 | | | | | | | | | |
| 72.5 | 96.5 | 128 | 164 | | | | | | | | | |
| 87 | 115.8 | 153.6 | 196.8 | | | | | | | | | |
| 101.5 | 135.1 | 179.2 | 229.6 | | | | | | | | | |
| 116 | 154.4 | 204.8 | 262.4 | | | | | | | | | |
| 130.5 | 173.7 | 230.4 | 295.2 | | | | | | | | | |
| 145 | 193 | 256 | 328 | | | | | | | | | |
| | 14.5 29 43.5 58 72.5 87 101.5 116 130.5 | 14.5 19.3 29 38.6 43.5 57.9 58 77.2 72.5 96.5 87 115.8 101.5 135.1 116 154.4 130.5 173.7 | 14.5 19.3 25.6 29 38.6 51.2 43.5 57.9 76.8 58 77.2 102.4 72.5 96.5 128 87 115.8 153.6 101.5 135.1 179.2 116 154.4 204.8 130.5 173.7 230.4 | | | | | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart



UNIVERSITY/COLLEGE DORMITORIES

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 19.0 | | 1 | | | 28.5 | 2 | | | | 38.0 | | 2 | | |
| 50 | 24.8 | | | 1 | | 37.1 | | 2 | | | 49.5 | | | 2 | |
| 100 | 34.0 | | 2 | | | 51.0 | | | 2 | | 68.0 | | | 3 | |
| 150 | 38.3 | | 2 | | | 57.4 | | | | 2 | 76.5 | | | 3 | |
| 200 | 44.0 | | | 2 | | 66.0 | | | | 2 | 88.0 | | | | 3 |
| 250 | 47.5 | | | 2 | | 71.2 | | | 3 | | 95.0 | | | | 3 |
| 300 | 51.1 | | | 2 | | 76.6 | | | 3 | | 102.2 | | | 4 | |
| 350 | 55.0 | | | | 2 | 82.5 | | | | 3 | 110.0 | | | | 4 |
| 400 | 59.2 | | | | 2 | 88.8 | | | | 3 | 118.4 | | | | 4 |
| 550 | 65.6 | | | | 2 | 98.4 | | | | 3 | 131.2 | | | | 4 |
| 700 | 76.8 | | | 3 | | 115.2 | | | | 4 | 153.6 | | | | 5 |
| 1000 | 96.4 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 1200 | 106.4 | | | | 4 | 159.6 | | | | 5 | 196.8 | | | | 6* |
| 1500 | 119.7 | | | | 4 | 164.0 | · | | | 5* | 196.8 | | | | 6* |
| 1800 | 139.5 | | | | 5 | 196.8 | | | | 6* | 229.6 | | | | 7* |
| 2200 | 153.0 | | - | | 5 | 196.8 | | - | | 6* | 229.6 | - | | | 7* |
| 3000 | 196.7 | | | | 6 | 229.6 | · | | | 7* | 262.4 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



HEALTH CLUBS, SPAS, YMCA/YWCA, AND COUNTRY CLUBS

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlig | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|---|---------|---------|-------------|--------|-----------|-----------|--------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | | INN1060 | INN1350 | _ | INN600 | | | | Load (GPM) | INN600 | | T | INN1350 |
| 25 | 10.3 | 1 | | | | 15.4 | 2 | | | | 20.5 | 2 | | | |
| 50 | 13.9 | 1 | | | | 20.8 | 2 | | | | 27.8 | 2 | | | |
| 100 | 19.3 | | 1 | | | 28.9 | 2 | | | | 38.6 | | 2 | | |
| 150 | 24.4 | | | 1 | | 36.6 | | 2 | | | 48.8 | | | 2 | |
| 200 | 27.6 | | | | 1 | 41.4 | | | 2 | | 55.3 | | | | 2 |
| 250 | 29.0 | | | | 1 | 43.5 | | | 2 | | 58.0 | | | | 2 |
| 300 | 30.8 | | | | 1 | 46.1 | | | 2 | | 61.5 | | | | 2 |
| 350 | 32.0 | | | | 1 | 48.0 | | | 2 | | 64.0 | | | | 2 |
| 400 | 34.4 | | 2 | | | 51.6 | | | 2 | | 68.8 | | | 3 | |
| 550 | 41.1 | | | 2 | | 61.7 | | | | 2 | 82.3 | | | | 3 |
| 700 | 47.1 | | | 2 | | 70.7 | | | 3 | | 94.3 | | | | 3 |
| 1000 | 57.4 | | | | 2 | 86.1 | | | | 3 | 114.8 | | | | 4 |
| 1200 | 63.3 | | | | 2 | 94.9 | | | | 3 | 126.5 | | | | 4 |
| 1500 | 70.9 | | | 3 | | 106.3 | | | | 4 | 141.8 | | | | 5 |
| 1800 | 75.4 | | | 3 | | 113.1 | | | | 4 | 150.8 | | | | 5 |
| 2200 | 84.4 | | | | 3 | 126.6 | | | | 4 | 164.0 | | | | 5* |
| 3000 | 106.4 | - | | | 4 | 159.6 | | - | | 5 | 196.8 | - | - | | 6* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES: * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



PRISONS AND CORRECTIONAL FACILITIES

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 19.0 | | 1 | | | 28.5 | 2 | | | | 38.0 | | 2 | | |
| 50 | 24.8 | | | 1 | | 37.1 | | 2 | | | 49.5 | | | 2 | |
| 100 | 34.0 | | 2 | | | 51.0 | | | 2 | | 68.0 | | | 3 | |
| 150 | 38.3 | | 2 | | | 57.4 | | | | 2 | 76.5 | | | 3 | |
| 200 | 44.0 | | | 2 | | 66.0 | | | | 2 | 88.0 | | | | 3 |
| 250 | 47.5 | | | 2 | | 71.2 | | | 3 | | 95.0 | | | | 3 |
| 300 | 51.1 | | | 2 | | 76.6 | | | 3 | | 102.2 | | | 4 | |
| 350 | 55.0 | | | | 2 | 82.5 | | | | 3 | 110.0 | | | | 4 |
| 400 | 59.2 | | | | 2 | 88.8 | | | | 3 | 118.4 | | | | 4 |
| 550 | 65.6 | | | | 2 | 98.4 | | | | 3 | 131.2 | | | | 4 |
| 700 | 76.8 | | | 3 | | 115.2 | | | | 4 | 153.6 | | | | 5 |
| 1000 | 96.4 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 1200 | 106.4 | | | | 4 | 159.6 | | | | 5 | 196.8 | | | | 6* |
| 1500 | 119.7 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 1800 | 139.5 | | | | 5 | 196.8 | | | | 6* | 229.6 | | | | 7* |
| 2200 | 153.0 | | | | 5 | 196.8 | | - | | 6* | 229.6 | | | | 7* |
| 3000 | 196.7 | | · | | 6 | 229.6 | · | | · | 7* | 262.4 | | | | 8* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES: * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.

^{****}If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.

^{****}See GF-5080 for commercial laundry system sizing guidelines.



OFFICE, COMMERCIAL, RETAIL

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | Design Load | | | 150% Design | Mutliples @ 150% Design Load | | | n Load | 200% Design | n Multiples @ 200% Design | | n Load | |
|------------|-------------|--------|-------------|---------|---------|-------------|------------------------------|--------|---------|---------|-------------|---------------------------|--------|---------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 8.2 | 1 | | | | 12.3 | 2 | | | | 16.4 | 2 | | | |
| 50 | 11.1 | 1 | | | | 16.7 | 2 | | | | 22.2 | 2 | | | |
| 100 | 15.9 | | 1 | | | 23.9 | 2 | | | | 31.8 | | 2 | | |
| 150 | 19.3 | | 1 | | | 28.9 | 2 | | | | 38.5 | | 2 | | |
| 200 | 22.1 | | | 1 | | 33.2 | | 2 | | | 44.2 | | | 2 | |
| 250 | 23.6 | | | 1 | | 35.4 | | 2 | | | 47.2 | | | 2 | |
| 300 | 24.6 | | | 1 | | 36.9 | | 2 | | | 49.2 | | | 2 | |
| 350 | 25.6 | | | 1 | | 38.4 | | 2 | | | 51.2 | | | 2 | |
| 400 | 27.5 | | | | 1 | 41.3 | | | 2 | | 55.0 | | | | 2 |
| 550 | 32.8 | | | | 1 | 49.2 | | | 2 | | 65.6 | | | | 2 |
| 700 | 37.7 | | 2 | | | 56.6 | | | | 2 | 75.4 | | | 3 | |
| 1000 | 45.9 | | | 2 | | 68.9 | | | 3 | | 91.8 | | | | 3 |
| 1200 | 50.6 | | | 2 | | 75.9 | | | 3 | | 101.2 | | | 4 | |
| 1500 | 56.7 | | · | · | 2 | 85.1 | · | | · | 3 | 113.4 | | | | 4 |
| 1800 | 60.3 | | | | 2 | 90.5 | | | | 3 | 120.6 | | | | 4 |
| 2200 | 65.6 | | | | 2 | 98.5 | | | | 3 | 131.2 | | | | 4 |
| 3000 | 85.1 | | · | | 3 | 127.7 | · | | · | 4 | 164.0 | | | | 5* |

| Maxim | Maximum Unit Capacity (GPM), 40-120 °F | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 | | | | | | | | |
| 2 | 29 | 38.6 | 51.2 | 65.6 | | | | | | | | |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 | | | | | | | | |
| 4 | 58 | 77.2 | 102.4 | 131.2 | | | | | | | | |
| 5 | 72.5 | 96.5 | 128 | 164 | | | | | | | | |
| 6 | 87 | 115.8 | 153.6 | 196.8 | | | | | | | | |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 | | | | | | | | |
| 8 | 116 | 154.4 | 204.8 | 262.4 | | | | | | | | |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 | | | | | | | | |
| 10 | 145 | 193 | 256 | 328 | | | | | | | | |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



INDUSTRIAL PLANT

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | Desig | n Load | | 150% Design | Mutlip | oles @ 15 | 0% Desigr | n Load | 200% Design | Multip | oles @ 20 | 0% Desigr | n Load |
|-------------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 25 | 8.2 | 1 | | | | 12.3 | 2 | | | | 16.4 | 2 | | | |
| 50 | 11.1 | 1 | | | | 16.7 | 2 | | | | 22.2 | 2 | | | |
| 100 | 15.9 | | 1 | | | 23.9 | 2 | | | | 31.8 | | 2 | | |
| 150 | 19.3 | | 1 | | | 28.9 | 2 | | | | 38.5 | | 2 | | |
| 200 | 22.1 | | | 1 | | 33.2 | | 2 | | | 44.2 | | | 2 | |
| 250 | 23.6 | | | 1 | | 35.4 | | 2 | | | 47.2 | | | 2 | |
| 300 | 24.6 | | | 1 | | 36.9 | | 2 | | | 49.2 | | | 2 | |
| 350 | 25.6 | | | 1 | | 38.4 | | 2 | | | 51.2 | | | 2 | |
| 400 | 27.5 | | | | 1 | 41.3 | | | 2 | | 55.0 | | | | 2 |
| 550 | 32.8 | | | | 1 | 49.2 | | | 2 | | 65.6 | | | | 2 |
| 700 | 37.7 | | 2 | | | 56.6 | | | | 2 | 75.4 | | | 3 | |
| 1000 | 45.9 | | | 2 | | 68.9 | | | 3 | | 91.8 | | | | 3 |
| 1200 | 50.6 | | | 2 | | 75.9 | | | 3 | | 101.2 | | | 4 | |
| 1500 | 56.7 | | | | 2 | 85.1 | | | | 3 | 113.4 | | | | 4 |
| 1800 | 60.3 | | | | 2 | 90.5 | | | | 3 | 120.6 | | | | 4 |
| 2200 | 65.6 | | | | 2 | 98.5 | | | | 3 | 131.2 | | | | 4 |
| 3000 | 85.1 | | | | 3 | 127.7 | | | | 4 | 164.0 | | | | 5* |

| Maximum Unit Capacity (GPM), 40-120 °F | | | | | | | | | | | |
|--|--------|--------|---------|---------|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 | | | | | | | |
| 2 | 29 | 38.6 | 51.2 | 65.6 | | | | | | | |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 | | | | | | | |
| 4 | 58 | 77.2 | 102.4 | 131.2 | | | | | | | |
| 5 | 72.5 | 96.5 | 128 | 164 | | | | | | | |
| 6 | 87 | 115.8 | 153.6 | 196.8 | | | | | | | |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 | | | | | | | |
| 8 | 116 | 154.4 | 204.8 | 262.4 | | | | | | | |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 | | | | | | | |
| 10 | 145 | 193 | 256 | 328 | | | | | | | |

NOTES:

- * When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.
- ****If this facility has sustained peak shower loads where 80-100% of the showers are typically on at the same time; use the "Group Shower Load" sizing chart.



RESTAURANT

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Fixture | Design Load | | | n Load | | 150% Design | Mutli | oles @ 15 | 0% Design | n Load | 200% Design | Multip | oles @ 20 | 0% Design | n Load |
|------------|-------------|--------|--------|---------|---------|-------------|--------|-----------|-----------|---------|-------------|--------|-----------|-----------|---------|
| Unit Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | _ | INN600 | INN800 | INN1060 | INN1350 | Load (GPM) | INN600 | INN800 | INN1060 | INN1350 |
| 5 | 19.3 | | 1 | | | 29.0 | 2 | | | | 38.6 | | 2 | | |
| 15 | 24.8 | | | 1 | | 37.3 | | 2 | | | 49.7 | | | 2 | |
| 25 | 29.0 | | | | 1 | 43.6 | | | 2 | | 58.1 | | | | 2 |
| 50 | 38.3 | | 2 | | | 57.4 | | | | 2 | 76.5 | | | 3 | |
| 75 | 46.9 | | | 2 | | 70.3 | | | 3 | | 93.8 | | | | 3 |
| 100 | 51.0 | | | 2 | | 76.5 | | | 3 | | 102.0 | | | 3 | |
| 150 | 59.9 | | | | 2 | 89.9 | | | | 3 | 119.8 | | | | 4 |
| 200 | 65.6 | | | | 2 | 98.4 | | | | 3 | 131.2 | | | | 4 |
| 250 | 73.1 | | | 3 | | 109.7 | | | | 4 | 146.3 | | | | 5 |
| 300 | 76.6 | | | 3 | | 114.9 | | | | 4 | 153.2 | | | | 5 |
| 350 | 83.1 | | | | 3 | 124.6 | | | | 4 | 164.0 | | | | 5* |
| 400 | 89.2 | | | | 3 | 131.2 | | | | 4* | 164.0 | | | | 5* |
| 550 | 112.1 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 700 | 130.4 | | | | 4 | 164.0 | | | | 5* | 196.8 | | | | 6* |
| 900 | 152.5 | | | | 5 | 196.8 | | | | 6* | 229.6 | | | | 7* |
| 1100 | 172.5 | | | | 6 | 229.6 | | | | 7* | 262.4 | | | | 8* |
| 1500 | 207.6 | | | | 7 | 262.4 | | | · | 8* | 256.0 | | · | | 9* |

| Maxim | num Unit Cap | acity (GPI | M), 40-12 | 0 °F |
|---------|--------------|------------|-----------|---------|
| # Units | INN600 | INN800 | INN1060 | INN1350 |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 |
| 2 | 29 | 38.6 | 51.2 | 65.6 |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 |
| 4 | 58 | 77.2 | 102.4 | 131.2 |
| 5 | 72.5 | 96.5 | 128 | 164 |
| 6 | 87 | 115.8 | 153.6 | 196.8 |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 |
| 8 | 116 | 154.4 | 204.8 | 262.4 |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 |
| 10 | 145 | 193 | 256 | 328 |

NOTES:

^{*} When design load requires 3 or more units, an additional 1-2 units will provide sufficient excess capacity.

^{**} Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.

^{***}Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.



GROUP SHOWER LOAD: GYMNASIUM, FIELD HOUSE, SPORTS ARENA, STADIUM, MILITARY BARRACKS, AND PRISONS

Domestic Water Inlet - Outlet Conditions: 40-120 °F

| Shower | Design Load | | | n Load | | Design Load W/N+1 Excess Capacity | | | | |
|--------|-------------|--------|--------|---------|---------|-----------------------------------|--------|---------|---------|--|
| Count | (GPM) | INN600 | INN800 | INN1060 | INN1350 | INN600 | INN800 | INN1060 | INN1350 | |
| 5 | 11.0 | 1 | | | | 2 | | | | |
| 10 | 21.9 | | | 1 | | | | 2 | | |
| 15 | 32.9 | | 2 | | | | 3 | | | |
| 20 | 43.8 | | | 2 | | | | 3 | | |
| 25 | 54.8 | | | | 2 | | | | 3 | |
| 30 | 65.6 | | | | 2 | | | | 3 | |
| 35 | 76.7 | | | 3 | | | | 4 | | |
| 40 | 87.6 | | · | | 3 | | | | 4 | |
| 45 | 98.6 | | | | 3 | | | | 4 | |

| Maxim | Maximum Unit Capacity (GPM), 40-120 °F | | | | | | | | | | | |
|---------|--|--------|---------|---------|--|--|--|--|--|--|--|--|
| # Units | INN600 | INN800 | INN1060 | INN1350 | | | | | | | | |
| 1 | 14.5 | 19.3 | 25.6 | 32.8 | | | | | | | | |
| 2 | 29 | 38.6 | 51.2 | 65.6 | | | | | | | | |
| 3 | 43.5 | 57.9 | 76.8 | 98.4 | | | | | | | | |
| 4 | 58 | 77.2 | 102.4 | 131.2 | | | | | | | | |
| 5 | 72.5 | 96.5 | 128 | 164 | | | | | | | | |
| 6 | 87 | 115.8 | 153.6 | 196.8 | | | | | | | | |
| 7 | 101.5 | 135.1 | 179.2 | 229.6 | | | | | | | | |
| 8 | 116 | 154.4 | 204.8 | 262.4 | | | | | | | | |
| 9 | 130.5 | 173.7 | 230.4 | 295.2 | | | | | | | | |
| 10 | 145 | 193 | 256 | 328 | | | | | | | | |

NOTES:

- * This sizing is based on 2.5 GPM shower heads, 110°F fixture outlet temperature, all showers are on full for 15 minutes, and the tank recovery time (when employed) can be up to 20 minutes.
- ** Selections for altitudes less than 5000'. For higher altitudes, find ACF (altitude correction factor) on pg. D300.0 and divide actual fixture count by ACF, then select based on calculated values.
- ***Based on 40 °F inlet and building recirculation. For alternate inlet temperatures, find TCF (temperature correction factor) on p. D300.1 and multiply actual fixture count by TCF, then select based on calculated values.
- **** When storage tanks are employed, 140 °F is the minimum domestic hot water setpoint. See pg. D300.14 for sizing recommendation above 30 shower heads.