



NOTES:

1. FOR ACTUAL SIZES AND LOCATIONS OF PIPING AND OTHER CONNECTIONS TO THE UNIT, SEE DIMENSIONAL DRAWING AP-A-943.
2. DRAIN VALVE AND CONDENSATE DRAIN HOSE SHOULD BE ARRANGED TO PERMIT THE FLUIDS TO DRAIN FREELY BY GRAVITY TO A CONVENIENT FLOOR DRAIN. THE RELIEF VALVE SHOULD BE PIPED VERTICALLY TO A HEIGHT 18" ABOVE THE FLOOR.
3. ALL PIPING AND ELECTRIC CONNECTIONS (SERVICE SWITCHES, CONDUIT BOXES, ETC.) SHOULD BE 6" AWAY FROM SIDE PANELS.
4. MANDATORY: PRIMARY PUMP - SEE AM SERIES PRIMARY LOOP DESIGN DATA - ENGR. MANUAL C400.4 OR PIPING APPLICATION GUIDE GF-146-P.
5. MANDATORY: BOILER STRAINER (20 MESH OR FINER).
6. RECOMMENDED: GAS REGULATOR (AND IS MANDATORY WHEN SUPPLY PRESSURE IS GREATER THAN 13" W.C.)
7. THIS IS A TYPICAL INSTALLATION DRAWING. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.
8. LOCATE DHW SENSOR (INCLUDED) OR REMOTE AQUASTAT IN LOWER 1/3 OF TANK.

* ITEMS SHIPPED WITH UNITS

INSTRUMENT LEGENDS			
(TS)	TEMPERATURE SENSOR		GAS PRESSURE REGULATOR
(TI)	THERMOMETER		RELIEF VALVE
(PI)	PRESSURE GAUGE		CHECK VALVE
	BALL VALVE		STRAINER
	UNION CONNECTION		MIXING VALVE

AERCO INTERNATIONAL, INC.
Blauvelt, NY 10913

**(3) AM 750 GAS FIRED WATER HEATERS
COMMON TANK INSTALLATION**

DWN. BY <u>S.S.</u> DATE <u>011215</u>	SD-A-1048	REV. B
SCALE <u>NTS</u> APPD. <u>A.M.</u> DATE <u>011215</u>		