


NOTES:

1. FOR ACTUAL SIZES AND LOCATIONS OF PIPING AND OTHER CONNECTIONS TO THE HEATER, SEE DIMENSIONAL DRAWING AP-A-1055.
2. REDUCERS, ON THE WATER INLET SIDE, SHOULD BE LOCATED ADJACENT TO THE HEATER. EXPANSION FITTINGS, ON THE WATER INLET SIDE, SHOULD BE LOCATED AS FAR AS POSSIBLE FROM THE HEATER.
3. RELIEF VALVE DISCHARGE SHOULD BE PIPED TO THE NEAREST FLOOR DRAIN. WHEN NO FLOOR DRAIN IS AVAILABLE, THE RELIEF VALVE DISCHARGE SHOULD BE PIPED VERTICALLY TO A HEIGHT 18" ABOVE THE FLOOR.

		100 ORITANI DRIVE BLAUVELT, NY 10913 aercocom
<b>SMARTPLATE EV 150/300 PSI          WATER TO WATER HEAT EXCHANGER          SINGLE UNIT INSTALLATION</b>		
DWN. BY <u>K.S.</u> DATE <u>071420</u> SCALE <u>NTS</u> SIZE <u>A</u> CHKD. _____ APPD. _____ REV. DATE _____	<b>SD-A-1198</b>	REV. <b>A</b>