

Maintenance and Preventative Kits

Modulex and Modulex EXT

Modulex EXT

To ensure continued safe, reliable, and efficient operation of your Modulex EXT boiler, regular maintenance and inspection must be performed in accordance to the user manual. AERCO offers a complete line of maintenance kits and fireside inspection kits.

- The Maintenance Kits consist of the spark ignitor and flame detector (with gaskets) for each module
- The Fireside Inspection Kits consist of the spark ignitor, flame detector, and burner gasket for each module.

Note: The Fireside Inspection Kit already includes the components included in the Maintenance Kit - therefore, when performing the Fireside Inspection, you only need the Fireside Inspection Kit, not both.


Estimated Labor Time:

- Maintenance Kits: 30-90 minutes (dependent on boiler size)
- Fireside Inspection Kits: 1-3 hours (dependent on boiler size)

For further information visit aerco.com.



Typical components of a Maintenance Kit



Typical components of a Fireside Inspection Kit



| Kit Type | Part Number |
|---|-------------|
| MLX EXT 321 Maintenance Kit | 58086-01 |
| MLX EXT 481/450 Maintenance Kit | 58086-02 |
| MLX EXT 641/600/1530/1500 Maintenance Kit | 58086-03 |
| MLX EXT 802/800/1912 Maintenance Kit | 58086-04 |
| MLX EXT 962/2295/2300 Maintenance Kit | 58086-05 |
| MLX EXT 1123/1100/2677/2600 Maintenance Kit | 58086-06 |
| MLX EXT 3060 Maintenance Kit | 58086-11 |
| MLX EXT 321 Fireside Inspection Kit | 58086-12 |
| MLX EXT 481/450 Fireside Inspection Kit | 58086-13 |
| MLX EXT 641/600 Fireside Inspection Kit | 58086-14 |
| MLX EXT 802/800 Fireside Inspection Kit | 58086-15 |
| MLX EXT 962 Fireside Inspection Kit | 58086-16 |
| MLX EXT 1123/1100 Fireside Inspection Kit | 58086-17 |
| MLX EXT 1530/1500 Fireside Inspection Kit | 58086-18 |
| MLX EXT 1912 Fireside Inspection Kit | 58086-19 |
| MLX EXT 2295/2300 Fireside Inspection Kit | 58086-20 |
| MLX EXT 2677/2600 Fireside Inspection Kit | 58086-21 |
| MLX EXT 3060/3000 Fireside Inspection Kit | 58086-22 |

Modulex

To perform the necessary tasks indicated in the maintenance schedule of the Modulex O&M, AERCO offers a complete line of maintenance kits and fireside inspection kits.

- The Maintenance Kits consist of the spark ignitor and flame detector (with gaskets) for each module.
- The Fireside Inspection Kits consist of the spark ignitor, flame detector, and burner gasket for each module, flue collector gasket, and exhaust connector gasket.

Note: The Fireside Inspection Kit already includes the components included in the Maintenance Kit - therefore, when performing the Fireside Inspection, you only need the Fireside Inspection Kit, not both.

Estimated Labor Time:

- Maintenance Kits: 30 minutes
- Fireside Inspection Kits: 1-3 hours (dependent on kit)

For further information visit aerco.com.



Typical components of a Maintenance Kit



Typical components of a Fireside Inspection Kit

| Kit Type | Part Number |
|------------------------------|-------------|
| MLX-303 Maintenance Kit | 58019-01 |
| MLX-454 Maintenance Kit | 58019-02 |
| MLX-606 Maintenance Kit | 58019-03 |
| MLX-757 Maintenance Kit | 58019-04 |
| MLX-909 Maintenance Kit | 58019-05 |
| MLX-1060 Maintenance Kit | 58019-06 |
| MLX-303 Fire Inspection Kit | 58019-07 |
| MLX-454 Fire Inspection Kit | 58019-08 |
| MLX-606 Fire Inspection Kit | 58019-09 |
| MLX-757 Fire Inspection Kit | 58019-10 |
| MLX-909 Fire Inspection Kit | 58019-11 |
| MLX-1060 Fire Inspection Kit | 58019-12 |