



NOTES:

- 1) FOR ACTUAL SIZES AND LOCATIONS OF PIPING AND OTHER CONNECTIONS TO THE WATER HEATER, SEE APPROPRIATE DIMENSIONAL DRAWING.
- 2) DRAIN VALVE AND CONDENSATE DRAIN HOSE SHOULD BE ARRANGED TO PERMIT THE FLUIDS TO DRAIN FREELY, BY GRAVITY, TO A CONVENIENT FLOOR DRAIN. RELIEF VALVES SHOULD NOT BE COMMON MANIFOLDED TOGETHER AND INDIVIDUALLY PIPED TO A HEIGHT OF 6" ABOVE FLOOR.
- 3) ALL PIPING AND ELECTRIC CONNECTIONS (SERVICE SWITCHES, CONDUIT BOXES) SHOULD BE A MINIMUM OF 6" AWAY FROM SIDE PANELS.
- 4) GAS REGULATOR IS REQUIRED WHEN SUPPLY PRESSURE IS GREATER THAN 13" W.C.
- 5) THIS IS A TYPICAL INSTALLATION DRAWING. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.

<b>AERCO</b> INTERNATIONAL, INC. Blauvelt, NY 10913	
AMR MODELS 199-500 INTEGRATED STYLE SINGLE UNIT INSTALLATION	
DWN. BY <u>K.S.</u> DATE <u>050615</u>	REV <u>B</u>
SCALE <u>NTS</u>	SD-A-1074
REVD DATE _____	