



Pipe Temp.	Line Type
CW	
HW	
Recirc	
Tempered	

- Ball Valve
- Check Valve
- Drain Valve
- Strainer
- Thermometer
- Backflow Preventer
- Balancing Valve Circuit Setter
- T&P Relief Valve
- Floor Drain
- Sequencing Valve

- NOTES:
1. FOR ACTUAL SIZES AND LOCATIONS OF PIPING AND OTHER CONNECTIONS TO THE HEATER, SEE DIMENSIONAL DRAWING.
  2. THIS IS A TYPICAL INSTALLATION DRAWING. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.
  3. LOCATE WATER INLET AND OUTLET FITTINGS (i.e. UNIONS, ELBOWS, ETC.) A MINIMUM OF 6" FROM WATER HEATER FITTINGS, TO PREVENT INTERFERENCE WITH REMOVAL OF HEATER PANELS.
  4. PIPE T&P VALVE TO WITHIN 6" OF DRAIN WITH NO SHUTOFF VALVES OR RESTRICTION IN THE LINE; OR PER LOCAL CODE REQUIREMENTS. CONDENSATE DRAIN LINE WITH NEUTRALIZER PIPED TO FLOOR DRAIN NOT SHOWN. DUPLICATE REQUIRED PIPING FOR HEATER(S) AND STORAGE TANK(S).
  5. IF PERMITTED BY LOCAL CODES, A CHECK VALVE MAY BE USED IN PLACE OF A BACKFLOW PREVENTER.
  6. REFER TO INSTALLATION CHAPTER OF OMM-0143 FOR AIR, GAS, AND CONDENSATE CONNECTIONS.
  7. ALL (\*) COMPONENTS ARE OPTIONAL FOR INSTALLATION UNLESS OTHERWISE STATED PER LOCAL CODE REQUIREMENTS.
  8. THE FOLLOWING COMPONENTS SHALL BE FIELD SOURCED: CHECK VALVES, STRAINERS, BALL VALVES, BALANCING VALVES, PUMPS, TEMPERATURE SENSORS, EXPANSION TANK, BACKFLOW PREVENTER.
  9. BUILDING RECIRC PUMP DETERMINED BY PLUMBING ENGINEER AND MINIMUM FLOW VARIES BY DIGITEMP MODEL.
  10. HEATERS SHOULD BE PIPED REVERSE RETURN AS SHOWN OR BALANCING DEVICES ON THE OUTLETS OF THE HEATERS SHOULD BE EMPLOYED.
  11. MOTORIZED/SEQUENCING VALVE WIRED INTO EACH UNIT'S INPUT/OUTPUT BOX CONNECT "AOUT" PER DRAWING SD-A-878.
  12. SEE CLEARANCE DIAGRAMS FOR APPROXIMATE INSTALLED FOOTPRINT WIDTH AND DEPTH.

		Blauvelt, NY 10913	
INNOVATION – MULT UNIT, NO STORAGE TANK, SEQUENCING VALVES			
DRWN BY. AK	DATE 083123	DWG. NO: SD-A-1330 Page 1 of 1	REV. A