



INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:
 LEFT & RIGHT SIDES: 24"
 FRONT: 24"
 REAR: 24"
 CEILING HEIGHT: 100"
- 3) REMOVAL OF IN-BETWEEN SIDE PANELS REQUIRED ONLY WHEN USING 14" SIDE AIR INLET TO SUPPLY COMBUSTION AIR TO BOTH UNITS.

- NOTES:
1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
 2. WHEN USING THE AERCO CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.
 3. SECONDARY INLET IS OPTIONAL. FEATURE CAN BE SELECTED WHEN CONFIGURING A BOILER ORDER.
 4. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.

 <small>A WATTS Brand</small>	100 ORITANI DRIVE BLAUVELT, NY 10913 aerco.com
BENCHMARK 4000/5000N BOILER ZERO SIDE CLEARANCE DIMENSIONAL DRAWING	
DWN. BY <u>K.S.</u> DATE <u>092319</u> SCALE <u>NTS</u> SIZE _____ CHKD. _____ APPD. _____ REV. BY <u>K.S.</u> DATE <u>062623</u>	SD-A-1191 C